



NOTES:

1. SEE E-001 FOR LEGEND AND GENERAL NOTES.
2. FOR LOCATION OF MDP, SEE EP100. FOR LOCATION OF HV7B, SEE EP107.
3. ALL WORK ASSOCIATED WITH CHILLER ACCH-4 TO BE PRICED AS ALTERNATE #4.

KEYED NOTES:

- ① PROVIDE 1 200A, 480V, 3 POLE, 65KA SYMMETRICAL, HACR TYPE, CIRCUIT BREAKER IN MDP.
- ② PROVIDE HEAT DETECTORS WITHIN 2' OF EACH SPRINKLER HEAD.

0	ISSUED FOR CONSTRUCTION	3-17-03
REV.	DESCRIPTION	DATE

ISSUED FOR CONSTRUCTION
3-17-03
 CURRENT ISSUE STATUS:



SMRT ARCHITECTURE ENGINEERING PLANNING
 SMRT
 144 Fore Street/P.O. Box 618
 Portland, Maine 04104
 tel. (207) 772-3846
 fax. (207) 772-1070

GLICKMAN LIBRARY
UNIVERSITY OF SOUTHERN MAINE
 PORTLAND, MAINE

ROOF POWER PLAN

SHEET TITLE:	ROOF POWER PLAN	
SCALE:	1/8"=1'-0"	DATE:
PROJECT MANAGER:	SLB	GRAPHIC SCALE:
JOB CAP/DRAWN:	CTB/JAC	
A/E OF RECORD:	JPP	SHEET No.
SMRT CAD FILE:	EP108-99092	EP108
PROJECT No.	99092	