



NOTES:

1. SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
2. ELEVATOR LOBBY 106 SMOKE DETECTOR NEEDS TO BE WIRED TO THE ELEVATOR RECALL OF THE 2 NEW ELEVATORS. WIRING ASSOCIATED WITH ELEVATOR #3 TO BE PRICED AS ALTERNATE #6.

KEYED NOTES:

- ① EXISTING VOICE/DATA OUTLETS MOUNTED IN FLOOR.
- ② EXISTING HEAT DETECTOR SHOWN IN RELOCATED POSITION.

0	ISSUED FOR CONSTRUCTION	3-17-03
REV.	DESCRIPTION	DATE

ISSUED FOR CONSTRUCTION
3-17-03
 CURRENT ISSUE STATUS:



SMRT ARCHITECTURE ENGINEERING PLANNING
 SMRT
 144 Fore Street/P.O. Box 618
 Portland, Maine 04104
 tel. (207) 773-3846
 fax. (207) 772-1070

GLICKMAN LIBRARY
UNIVERSITY OF SOUTHERN MAINE
 PORTLAND, MAINE

PROJECT:
FIRST FLOOR
SYSTEMS PLAN

SHEET TITLE:	SCALE: 1/8"=1'-0"	DATE:
PROJECT MANAGER: SLB	GRAPHIC SCALE: 0" 1"	
JOB CAP/DRAWN: CTB/JAC	A/E OF RECORD: JPP	SHEET No.
SMRT CAD FILE: EY101-99092	PROJECT No. 99092	EY101

A1 FIRST FLOOR PLAN
 1/8"=1'-0"