



NOTES:

- SEE E-001 FOR LEGEND AND GENERAL NOTES.
- ELEVATOR LOBBY 606 SMOKE DETECTOR NEEDS TO BE WIRED TO THE ELEVATOR RECALL OF THE 2 NEW ELEVATORS. WIRING ASSOCIATED WITH ELEVATOR #3 TO BE PRICED AS ALTERNATE #6.
- COORDINATE CABLE TRAY INSTALLATION WITH MECHANICAL DUCT WORK.
- SPECIAL COLLECTIONS STACKS (619) AND OSHER STORAGE (606) WILL HAVE A DOUBLE INTERLOCK PREACTION SPRINKLER SYSTEM. HEAT DETECTORS SHALL HAVE 2 N.O. CONTACTS.
- THERE WILL ONLY BE ONE AIR HANDLER (AHU-6) FOR BASE BID. ONE DUCT DETECTOR REQUIRED. UNDER ALTERNATE #4 THERE WILL BE TWO AIR HANDLERS (AHU-6A & 6B). ONE DUCT DETECTOR REQUIRED FOR EACH.

KEYED NOTES:

- MOUNT VOICE/DATA OUTLET BOX 48" AFF.
- PROVIDE CONDUIT BETWEEN CEILING MOUNTED VOICE/DATA OUTLET BOX AND CABLE TRAY FOR FUTURE WIRELESS TRANSCIVER.
- CORE DRILL FOR (3)-4" COMMUNICATION CONDUIT SLEEVES. EXTEND SLEEVES 6" ABOVE AND BELOW FLOOR.
- PROVIDE BOX IN WALL, 48" A.F.F., AND 3/4" CONDUIT BETWEEN BOX AND TELECOMMUNICATIONS TRAY FOR CARD ACCESS SYSTEM. CARD ACCESS EQUIPMENT & WIRING IS BY OWNER.

0	ISSUED FOR CONSTRUCTION	3-17-03
REV.	DESCRIPTION	DATE

ISSUED FOR CONSTRUCTION
3-17-03

CURRENT ISSUE STATUS:

PROJECT NORTH

SMRT ARCHITECTURE ENGINEERING PLANNING
 SMRT
 144 Fore Street/P.O. Box 618
 Portland, Maine 04104
 tel. (207) 773-3846
 fax. (207) 772-1070

GLICKMAN LIBRARY
UNIVERSITY OF SOUTHERN MAINE
 PORTLAND, MAINE

PROJECT:
SIXTH FLOOR
SYSTEMS PLAN

SHEET TITLE:	SCALE:	DATE:
PROJECT MANAGER: SLB	1/8"=1'-0"	GRAPHIC SCALE: 0" 1"
JOB CAP/DRAWN: CTB/JAC	A/E OF RECORD: JPP	SHEET No.
SMRT CAD FILE: EY106-99092	PROJECT No. 99092	EY106