



**NOTES:**

1. SEE E-001 FOR LEGEND AND GENERAL NOTES.
2. ELEVATOR LOBBY 706 SMOKE DETECTOR NEEDS TO BE WIRED TO THE ELEVATOR RECALL OF THE 2 NEW ELEVATORS. WIRING ASSOCIATED WITH ELEVATOR #3 TO BE PRICED AS ALTERNATE #6.
3. COORDINATE CABLE TRAY INSTALLATION WITH MECHANICAL DUCT WORK.
4. IN EVENTS SPACE 717, PROVIDE 4"x4" JUNCTION BOX AT EACH CEILING MOUNTED SOUND SPEAKER LOCATION AND 3/4" CONDUIT BETWEEN EACH JUNCTION BOX AND SOUND AMPLIFIER IN STORAGE 716. SOUND SPEAKERS, AMPLIFIER AND WIRING TO BE PROVIDED BY OWNER.

**KEYED NOTES:**

- ① MOUNT VOICE/DATA OUTLET BOX 48" AFF.
- ② PROVIDE CONDUIT BETWEEN CEILING MOUNTED VOICE/DATA OUTLET BOX AND CABLE TRAY FOR FUTURE WIRELESS TRANSCEIVER.
- ③ EXISTING HEAT DETECTOR TO BE RELOCATED FROM THE BUILDING STRUCTURE TO SUSPENDED CEILING MOUNTED.
- ④ CORE DRILL FOR (3)-4" COMMUNICATION CONDUIT SLEEVES. EXTEND SLEEVES 6" ABOVE AND BELOW FLOOR.

0	ISSUED FOR CONSTRUCTION	3-17-03
REV.	DESCRIPTION	DATE

**ISSUED FOR CONSTRUCTION**  
**3-17-03**

CURRENT ISSUE STATUS:

PROJECT NORTH

ARCHITECTURE ENGINEERING PLANNING  
 SMRT  
 144 Fore Street/P.O. Box 618  
 Portland, Maine 04104  
 tel. (207) 772-3846  
 fax. (207) 772-1070

**GLICKMAN LIBRARY**  
**UNIVERSITY OF SOUTHERN MAINE**  
 PORTLAND, MAINE

**SEVENTH FLOOR**  
**SYSTEMS PLAN**

SHEET TITLE:	SEVENTH FLOOR SYSTEMS PLAN	
SCALE:	1/8"=1'-0"	DATE:
PROJECT MANAGER:	SLB	GRAPHIC SCALE:
JOB CAP/DRAWN:	CTB/JAC	1" = 10'-0"
A/E OF RECORD:	JPP	SHEET No.
SMRT CAD FILE:	EY107-99092	<b>EY107</b>
PROJECT No.	99092	