

**City of Portland, Maine - Building or Use Permit Application**

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No:	Issue Date:	CBL:
08-0729		114 D023001


Location of Construction: 65 WINSLOW ST	Owner Name: UNIVERSITY OF MAINE SYSTE	Owner Address: 96 FALMOUTH ST	Phone:
Business Name:	Contractor Name: Nason Mechanical Systems	Contractor Address: 194 Merrow Road Auburn	Phone 2077820707
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	Zone: B-6

Past Use: University of Southern Maine Connected w/ permit#071236	Proposed Use: University of Southern Maine Connected w/ permit#071236 - New Boiler & Air Handlers - Raytherm Heating boilers	Permit Fee: \$2,020.00	Cost of Work: \$200,000.00	CEO District: 2	Zone: USM overlay
Proposed Project Description: New Boiler & Air Handlers - Raytherm Heating boilers		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied TO NFPA 54 & 90B		INSPECTION: Use Group: Type: HVAC Date: 6/25/08	
		Signature: <i>Craig Carr</i>		Signature: <i>[Signature]</i>	

PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)	
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied	
Signature: Date:	

Permit Taken By: Idobson	Date Applied For: 06/19/2008	<b>Zoning Approval</b>
-----------------------------	---------------------------------	------------------------

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.



<b>Special Zone or Reviews</b> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date: <i>6/23/08</i>	<b>Zoning Appeal</b> <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	<b>Historic Preservation</b> <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: <i>[Signature]</i>
--	---	---

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT

ADDRESS

DATE

PHONE

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE

DATE

PHONE



FILL IN AND SIGN WITH INK

# APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL FOREST AVE / BENNETT AVE Use of Building LIBRARY Date 6/18/08  
Name and address of owner of appliance UNIVERSITY OF SOUTHERN MAINE

Installer's name and address NASON MECHANICAL SYSTEMS  
194 MERROW RD. AUBURN, ME 04210 Telephone 207-782-0727

## Location of appliance:

- ☒ Basement ☐ Floor  
☐ Attic ☐ Roof

## Type of Fuel:

- ☒ Gas ☐ Oil ☐ Solid

Appliance Name: BOILER / AIR HANDLERS

U.L. Approved ☐ Yes ☐ No

Will appliance be installed in accordance with the manufacture's installation instructions? ☒ Yes ☐ No

IF NO Explain: \_\_\_\_\_

## The Type of License of Installer:

- ☐ Master Plumber # \_\_\_\_\_  
☐ Solid Fuel # \_\_\_\_\_  
☐ Oil # \_\_\_\_\_  
☒ Gas # PNT 4755  
☐ Other \_\_\_\_\_

## Type of Chimney:

- ☐ Masonry Lined  
Factory built \_\_\_\_\_

- ☒ Metal  
Factory Built U.L. Listing # \_\_\_\_\_

- ☐ Direct Vent  
Type \_\_\_\_\_ UL# \_\_\_\_\_

## Type of Fuel Tank

- ☐ Oil  
☐ Gas

N/A JUN 19 2008

Size of Tank \_\_\_\_\_

Number of Tanks \_\_\_\_\_

Distance from Tank to Center of Flame \_\_\_\_\_ feet.

Cost of Work: \$ 200,000

Permit Fee: \$ 1,930

## Approved

Fire: \_\_\_\_\_

Ele.: \_\_\_\_\_

Bldg.: \_\_\_\_\_

Signature of Installer

[Signature]

## Approved with Conditions

- ☐ See attached letter or requirement

Inspector's Signature

Date Approved

White - Inspection

Yellow - File

Pink - Applicant's

Gold - Assessor's Copy

**City of Portland, Maine - Building or Use Permit**

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

<b>Permit No:</b> 08-0729	<b>Date Applied For:</b> 06/19/2008	<b>CBL:</b> 114 D023001
------------------------------	--	----------------------------

<b>Location of Construction:</b> 65 WINSLOW ST	<b>Owner Name:</b> UNIVERSITY OF MAINE SYSTE	<b>Owner Address:</b> 96 FALMOUTH ST	<b>Phone:</b>
<b>Business Name:</b>	<b>Contractor Name:</b> Nason Mechanical Systems	<b>Contractor Address:</b> 194 Merrow Road Auburn	<b>Phone</b> (207) 782-0707
<b>Lessee/Buyer's Name</b>	<b>Phone:</b>	<b>Permit Type:</b> HVAC	

<b>Proposed Use:</b> University of Southern Maine Connected w/ permit#071236 - New Boiler & Air Handlers - Raytherm Heating boilers	<b>Proposed Project Description:</b> New Boiler & Air Handlers - Raytherm Heating boilers
--	--

<b>Dept:</b> Zoning	<b>Status:</b> Approved	<b>Reviewer:</b> Marge Schmuckal	<b>Approval Date:</b> 06/23/2008
<b>Note:</b>	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Dept:</b> Building	<b>Status:</b> Approved with Conditions	<b>Reviewer:</b> Tammy Munson	<b>Approval Date:</b> 07/16/2008
<b>Note:</b>	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
1) Installation shall comply with 2003 International Mechanical Code regarding the requirements of fire dampers and penetrations.			
2) The installation must comply with the State of Maine Gas Regulations.			
<b>Dept:</b> Fire	<b>Status:</b> Approved with Conditions	<b>Reviewer:</b> Capt Greg Cass	<b>Approval Date:</b> 06/24/2008
<b>Note:</b>	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
1) Install shall comply with NFPA 90 B and or NFPA 54. The more restrictive shall apply.			