



SHIP		BILL OF MATERIAL					
MARK	QUAN	PC MK	DESCRIPTION	FT	INCHES	WT	REMARKS
S1	ONE		STAIR STRINGER				HOT DIPPED GALV.
	ONE	mc1	MC12X10.2	23	11'8"	244.06	
	ONE	C1	L3X3X5/16	0	3	1.53	
	ONE	ba1	FB1/4X1 1/2	0	6 3/4	0.72	
	ONE	aa1	L2X2X1/4	1	7 1/4	5.12	
	2	pa1	1 1/4" SCH40	0	1 1/4	0.26	
S2	ONE		STAIR STRINGER				HOT DIPPED GALV.
	ONE	mc1	MC12X10.2	23	11'8"	244.06	
	ONE	C1	L3X3X5/16	0	3	1.53	
	ONE	ba1	FB1/4X1 1/2	0	6 3/4	0.72	
	ONE	aa1	L2X2X1/4	1	7 1/4	5.12	
T1	20		STAIR TREAD				
	20		GRATING 3/16x1x1'-0 1/8x2'-11 1/2	11 1/2		248.40	HOT DIPPED GALV.
	40	ba6	BAR 1/4x2 1/2	1	0 1/8	85.89	
A1	2		L2X2X1/4	1	4	8.51	
A2	ONE		L3X3X5/16	3	4	20.33	
P1	ONE	ab1	L3X3X3/8	5	10 1/4	42.15	
	ONE	bb6	FB1/2X3	0	8	3.40	
A3	ONE		L4X4X3/8	11	6	112.70	
A4	ONE		L4X4X3/8	12	3 1/2	120.46	

PRINT RECORD		MATERIAL: AS NOTED	
USE	QUAN	DATE	HOLES: 7/16" DIA. UON
OFA	5	7-12-07	ELECTRODES: E70XX
			FIELD CONN:
SHOP		SURFACE PREP: SSPC-SP3	
		PAINT: 1-S/C RED OXIDE PRIMER	
FIELD		REF. DWGS:	
CUSTOMER: WRIGHT-RYAN CONSTRUCTION			
JOB: UNIVERSITY COMMONS, U.S.M.			
DESCRIPTION: EXTERIOR GALV. STAIR AND RAILS			
ARCHITECT: KOETTER/KIM & ASSOCIATES INC.			
ENGINEER: WEIDLINGER			
DRAWN BY	JRC 6-25-07	CHKD BY	DRAWING NUMBER 6
			REVISION NUMBER
LMC LIGHT IRON, INC.			JOB NUMBER 2700
TEL: (207) 793-9957 E RANGE ROAD - P.O. BOX 521 LIMERICK, MAINE 04048 FAX: (207) 793-3919			

SUBMITTAL REVIEW:
 Submittal Package: 25504 Submittal No: _____
 REVIEWED-NO EXCEPTIONS TAKEN REVISE AND RESUBMIT
 NOTE MARKINGS REJECTED
 Reviewed for general conformance with the design concept and contract documents. Markings or comments shall not be construed as relieving the Subcontractor from compliance with the project plans and specifications, nor departure therefrom. The Subcontractor remains responsible for details and accuracy, for conforming and correlating all quantities and dimensions, for selecting fabrication processes, for techniques of assembly, and for performing the work in a safe manner.
WRIGHT-RYAN CONSTRUCTION, INC.
 BY: B. K. T. H. DATE: 10/25/07