



LINE	BILL OF MATERIAL							
	MARK	QUAN	PC MK	DESCRIPTION	FT	INCHES	WT	REMARKS
1	S1	ONE		STAIR STRINGER				HOT DIPPED GALV.
2		ONE	mc1	MC12X10.2	23	11 1/8	244.06	
3		ONE	C1	L3X3X5/16	0	3	1.53	
4		ONE	ba1	FB 1/4X1 1/2	0	6 3/4	0.72	
5		ONE	aa1	L2X2X1/4	1	7 1/4	5.12	
6		2	pa1	1 1/4 SCH40	0	1 1/4	0.26	
7								
8								
9								
10	S2	ONE		STAIR STRINGER				HOT DIPPED GALV.
11		ONE	mc1	MC12X10.2	23	11 1/8	244.06	
12		ONE	C1	L3X3X5/16	0	3	1.53	
13		ONE	ba1	FB 1/4X1 1/2	0	6 3/4	0.72	
14		ONE	aa1	L2X2X1/4	1	7 1/4	5.12	
15								
16								
17								
18	T1	20		STAIR TREAD				
19		20		GRATING 1/8X1X1'-0 1/8	2	11 1/2	248.40	HOT DIPPED GALV.
20		40	ba6	BAR 1/4X2 1/2	1	0 1/8	85.89	
21								
22								
23								
24	A1	2		L2X2X1/4	1	4	8.51	
25								
26	A2	ONE		L3X3X5/16	3	4	20.33	
27								
28								
29								
30	P1	ONE	ab1	L3X3X3/8	5	10 1/4	42.15	
31		ONE	bb6	FB 1/2X3	0	8	3.40	
32								
33								
34								
35								
36								
37	A3	ONE		L4X4X3/8	11	6	112.70	
38								
39	A4	ONE		L4X4X3/8	12	3 1/2	120.46	
40								
41								
42								
43								
44								
45								
46								
47								
48								

PRINT RECORD			MATERIAL: AS NOTED			
USE	QUAN	DATE	HOLES: 7/16" DIA. UON			
OFA	5	7-12-07	ELECTRODES: E70XX			
			FIELD CONN:			
SHOP			SURFACE PREP: SSPC-SP3			
			PAINT: 1-S/C RED OXIDE PRIMER			
FIELD			REF. DWGS:			

CUSTOMER: WRIGHT-RYAN CONSTRUCTION
 JOB: UNIVERSITY COMMONS, U.S.M.
 DESCRIPTION: EXTERIOR GALV. STAIR AND RAILS
 ARCHITECT: KOETTER/KIM & ASSOCIATES INC.
 ENGINEER: WEIDLINGER

DRAWN BY JRC 6-25-07	CHKD BY	DRAWING NUMBER 6	REVISION NUMBER
LMC LIGHT IRON, INC.			JOB NUMBER 2700
E RANGE ROAD - P.O. BOX 521 LIMERICK, MAINE 04048			TEL: (207) 793-9957 FAX: (207) 793-9919

SUBMITTAL REVIEW:
 Submittal Package: 05-500 Submittal No:
 REVIEWED-NO EXCEPTIONS TAKEN REVISE AND RESUBMIT
 NOTE MARKINGS REJECTED
 Reviewed for general conformance with the design concept and contract documents. Markings or comments shall not be construed as relieving the Subcontractor from compliance with the project plans and specifications, nor departure therefrom. The Subcontractor remains responsible for details and accuracy, for conforming and correlating all quantities and dimensions, for selecting fabrication processes, for techniques of assembly, and for performing the work in a safe manner.
 WRIGHT-RYAN CONSTRUCTION, INC.
 BY: B. J. [Signature] DATE: 10/25/07