



25 USM overlay

Entered 5/3/12 (135)

child 202-43530



### Fire Alarm Permit

Parent #: 2012-05-3904-HVAC 96 Falmouth

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

(96 Falmouth)  
LUTHER BOWNEY BUILDING

Installation address: BEDFORD ST, 85 CBL: 118-1114-A 001

Exact location: (within structure) 3- HVAC AIR HANDLERS

Type of occupancy(s) (NFPA & ICC): COMMERCIAL

Building owner: UNIVERSITY OF SOUTHERN MAINE

Must be

System Designer (point of contact): COLBY COMPANY

Designer phone: 207-563-7753 E-mail: EMILY@COLBYCOENGINEERING.COM

Installing contractor: JCN CONSTRUCTION Certificate of Fitness No: \_\_\_\_\_

Contractor phone: 603-624-7080 EXT: 409 E-mail: NMCELROY@JCNCONSTRUCTION.COM

This is a new application: YES  NO  New AES Master Box: YES  NO   
(Include Master Box approval form)

Amendment to an existing permit: YES  NO  Permit no: \_\_\_\_\_

The following documents shall be provided with this application:

- Floor plans
- Wiring diagram
- Annunciator details
- Input/ Output Matrix
- Equipment data sheets
- Electrical Permit Pulled (check alarm/com)
- Scope of Work
- 11 1/2 x 17s
- pdf copy (may be e-mailed)
- Designer qualifications
- Battery/ voltage drop calcs

Master box approval only: YES  NO   
(If yes check New AES Master Box above)

COST OF WORK: \$ 5,780 00 / 100

PERMIT FEE: \$ 75 00 / 100  
(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

RECEIVED

MAY 03 2012

Dept. of Building Inspections  
City of Portland Maine

The designer shall be the responsible party for this application. Download a new copy of this application at [www.portlandmaine.gov/fire](http://www.portlandmaine.gov/fire) for every submittal. Submit all plans in electronic PDF in addition to readable 11 1/2 x 17s to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire alarm system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with the City of Portland Technical Standard for Signaling Systems for the Protection of Life and Property, available at [www.portlandmaine.gov/fire](http://www.portlandmaine.gov/fire).

# DENIED

Applicant signature: Edward J McElroy Date: 4/26/2012



# PORTLAND MAINE

*Strengthening a Remarkable City, Building a Community for Life • [www.portlandmaine.gov](http://www.portlandmaine.gov)*

Receipts Details:

**Tender Information:** Check , Check Number: 74050

**Tender Amount:** 78.00

Receipt Header:

**Cashier Id:** bsaucier

**Receipt Date:** 5/3/2012

**Receipt Number:** 43531

# DENIED

Receipt Details:

Referance ID:	6369	Fee Type:	BP-FIRE
Receipt Number:	0	Payment Date:	
Transaction Amount:	78.00	Charge Amount:	78.00
Job ID: Job ID: 2012-05-3904-HVAC - Complete replacement of HVAC; Luther Bonney Build			
Additional Comments: 96 Falmouth (85 Bedford)			

Thank You for your Payment!

The fire alarm permit is being denied on the following basis:

1. Required documentation was not provided; and
2. Applicant does not have a certificate of fitness for master fire alarm company.

Spoke with the applicant on the phone on 6/13/12 at 11 am and was informed by them that they were only installing 3 duct detectors and do not require a fire alarm permit. They were informed that a master fire alarm company will have to test and certify the installation and provide a compliance report to the Fire Department at the completion of the job. The contractor will be using Norris as their master fire alarm company. Also the GC must use Maine licensed electricians.