

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 2013-00733	Date Applied For: 04/16/2013	CBL: 114A A001001
---------------------------------	--	-----------------------------

Location of Construction: 96 FALMOUTH ST	Owner Name: UNIVERSITY OF MAINE	Owner Address: 107 MAINE AVE	Phone: (207) 228-8124
Business Name:	Contractor Name: Doten Construction	Contractor Address: 175 South Freeport Rd. Freeport	Phone: (207) 865-9012
Lessee/Buyer's Name	Phone:	Permit Type: Alterations - Commercial	

Proposed Use: Same: University	Proposed Project Description: Replacement of curtain wall in Science Building; A Wing. Called 70 Falmouth St.
--	---

Dept: Zoning **Status:** Approved **Reviewer:** Marge Schmuckal **Approval Date:** 04/29/2013
Note: **Ok to Issue:**

Dept: Building **Status:** Approved w/Conditions **Reviewer:** Jeanie Bourke **Approval Date:** 05/14/2013
Note: **Ok to Issue:**

- 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 2) Permit approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

Dept: Fire **Status:** Approved w/Conditions **Reviewer:** Ben Wallace Jr **Approval Date:** 05/21/2013
Note: **Ok to Issue:**

- 1) All means of egress to remain accessible at all times.
- 2) Through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance rated horizontal assemblies shall be protected by firestop systems or devices in conformance with NFPA 101:8.3.5 (ASTM E 814 or ANSI/UL 1479). Providing firestop labels at each firestop system or device and an onsite manual containing the detail for each firestop system or device used for the project will streamline final inspection approvals.
- 3) All construction shall comply with City Code Chapter 10.