

NOTES:

1. SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
2. ALL RECEPTACLES AND CONDUITS FEEDING THEM IN ROOMS 200, 201 AND 202 TO BE EXPOSED SURFACE MOUNTED. CONDUITS SHALL BE EMT.
3. MINIMIZE NUMBER OF WALL PENETRATIONS INTO CYBER SECURITY ROOM TO THE EXTENT POSSIBLE. ALL PENETRATIONS SHALL BE COMPLETELY SEALED.

KEYED NOTES:

- ① PROVIDE JUNCTION BOX IN CEILING WITH A DOUBLE DUPLEX CORD DROP RECEPTACLE. CORD TO BE A 5' HEAVY DUTY CORD WITH KELLUMS STRAIN RELIEF GRIP. PROVIDE HOOK JUST BELOW CEILING TO BE USED TO COIL CORD DROPS TO GET THEM ABOVE CABLE TRAY.
- ② PROVIDE CEILING MOUNTED RECEPTACLE FOR OWNER PROVIDED PROJECTOR. COORDINATE WITH OWNER FOR EXACT LOCATIONS TO MOUNT RECEPTACLES.

144 Fore Street/P.O. Box 618
 Portland, Maine 04104
 tel. (207) 772-3846
 fax. (207) 772-1070
 www.smrinc.com

ARCHITECTURE
 ENGINEERING
 PLANNING
 INTERIOR DESIGN
 COMMISSIONING



USM SCIENCE BUILDING C WING
 CYBER SECURITY LAB FIT-UP
 PROJECT 2013-007
 PORTLAND, MAINE




ISSUED FOR PERMITTING AND CONSTRUCTION
 12-20-13
 CURRENT ISSUE STATUS:

REV	DESCRIPTION	DATE
0	ISSUED FOR PERMITTING AND CONSTRUCTION	12-20-13

SCALE: 1/4"=1'-0"
 PROJECT MANAGER: SLB
 JC/DRAWN BY: CDS
 A/E OF RECORD: DJT
 CAD FILE: EP401-12014-02
 PROJECT NO: 12014-02
 DATE: 12-20-13

SHEET TITLE:
ENLARGED POWER PLAN

SHEET No. **EP401**
 © COPYRIGHT 2012 SMRT INC.



SEAL