C7	UNDERCABINET LIGHTING DETAIL
SCALE: 1/4"=1'-0"	

F9	TYPICAL OCCUPANCY SENSOR CONNECTION
NO SCALE	

0 2' 4' 8'
Scale: 1/4" = 1'-0"

1. REMOVE EXISTING SWITCH AND LIGHT FIXTURES.
2. PROVIDE EMERGENCY SHUNT RELAY TO BYPASS SWITCHING FOR LIGHTING CONNECTED TO THE LIFE SAFETY BRANCH. CIRCUIT EDPL-8 IS THE EXISTING LIFE-SAFETY BRANCH CIRCUIT THAT SERVES THE EXISTING CORRIDOR.

A1	LIGHTING PLAN
SCALE: 1/4"=1'-0"	

A9	LIGHTING KEYED NOTES
NO SCALE	

HKTA / arch
HKTA / architects, inc.
482 Congress Street Suite 502
Portland, Me.
phone: 207. 774.
fax: 207. 774. 9125
email: hkta@maine.com

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/19/14

Allied Engineering
Structural Mechanical Electrical Commissioning
160 Veranda Street
Portland, Maine 04103
T: 207.221.2260
F: 207.221.2266
Web: www.allied-eng.com

CATHERINE A. FAUCHER No. 7531 LICENSED PROFESSIONAL ENGINEER STATE OF MAINE

REVISIONS

NUMBER	DATE	BY	DESCRIPTION

Date: 3/28/2014
Drawn By: GMC
Checked By: SRM
Project Mgr: IAM
Project No: 14003
Cad File: 14003E.DWG
Graphic Scale: 0 1"

LIGHTING PLAN

UNIVERSITY OF SOUTHERN MAINE BIO-SCIENCE
~ 3rd FLOOR LAB FIT-UP
PORTLAND, MAINE

© COPYRIGHT 2014 ALLIED ENGINEERING, INC.

EL-100

N:\Projects\2014\14003 - USM Bio Science\00 Drawing Files\14003E.dwg Mar 27, 2014 - 10:13am