

NOTES:



- SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
- FOR APPROXIMATE LOCATION OF MDP SEE EP101.
- PROVIDE A GFCI RECEPTACLE WITH WEATHERPROOF IN USE COVER NEAR ACC-1 IF NONE EXIST WITHIN 25'. PROVIDE CIRCUIT FROM 3RD FLOOR PANEL.

KEYED NOTES:

- INSTALL 6" ABOVE COUNTER.
- INSTALL 42" AFF TO CENTER.
- PROVIDE POWER TO PATIENT LIFT.
- RECEPTACLE IS LOCATED WITHIN RELOCATED HEADWALL.
- INSTALL IN CEILING 12' FROM PROJECTOR SCREEN.
- PROVIDE SINGLE POLE SWITCH WITH PILOT LIGHT. SWITCH SHALL CONTROL VACUUM PUMP LOCATED IN PENTHOUSE. SWITCH SHALL BE RATED 120V, 20A.
- CONNECT EXISTING RECEPTACLE TO NEW CIRCUIT AS SHOWN.
- REPLACE EXISTING 120V, 15A, 10,000 AIC PANEL CIRCUIT BREAKER WITH A 20A. VP-1 SHALL BE CONTROLLED FROM A TOGGLE SWITCH ON THE FIRST FLOOR. REFER TO EP101 FOR LOCATION. THE RECEPTACLE FOR THE EXISTING VACUUM PUMP SHALL BE CONTROLLED FROM A TOGGLE SWITCH ON THE THIRD FLOOR. SEE THIS DRAWING FOR LOCATION.
- REFER TO ALTERNATE #1.
- INSTALL 54" AFF TO CENTER.

144 Fore Street, P.O. Box 618
Portland, Maine 04104
Tel: (207) 772-3846
Fax: (207) 772-1070
www.smartinc.com

ARCHITECTURE
ENGINEERING
PLANNING
INTERIOR DESIGN
COMMISSIONING



UNIVERSITY OF SOUTHERN MAINE
SIMULATION LABORATORY
PORTLAND, MAINE

ISSUED FOR BIDDING & CONSTRUCTION
4-15-11

CURRENT ISSUE STATUS:

REV	DESCRIPTION	DATE
0	ISSUED FOR BIDDING, PERMITTING & CONSTRUCTION	4-15-11

GRAPHIC SCALE:
0" 1"

SCALE: 1/4"=1'-0"
PROJECT MANAGER: SLB
JC/DRAWN BY: CDS
A/E OF RECORD: JPB
CAD FILE: EP102-10150
PROJECT NO: 10150-00
DATE: 4-15-11
SHEET TITLE:
THIRD FLOOR
AND ROOF
POWER PLAN

SHEET No.
EP102
© COPYRIGHT 2009 SMART INC.

A1 THIRD FLOOR PLAN
1/4" = 1'-0"

A8 ROOF PART PLAN
1/16" = 1'-0"

A14 KEY PLAN
NTS