

NOTE:


- SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.

KEYED NOTES:

- IN EXISTING SQUARE D PANELBOARD FURNISH & INSTALL SIX NEW 20 AMP, SINGLE POLE CIRCUIT BREAKERS TO FEED NEW RECEPTACLES SHOWN ON EP401.
- IN EXISTING SQUARE D PANELBOARD UTILIZE NINETEEN EXISTING 20 AMP, SINGLE POLE CIRCUIT BREAKERS TO FEED NEW RECEPTACLES SHOWN ON EP101 AND EP401.
- EXTEND EXISTING WIRING FOR RELOCATED POWER POLE. SEE SHEET ED101 FOR CURRENT LOCATION OF POLE. COORDINATE WITH OWNER FOR EXACT LOCATION TO LOCATE POLE.

ALTERNATE #5

UNDER ALTERNATE #5 PROVIDE PRICING TO INSTALL EIGHT DOUBLE DUPLEX SURFACE MOUNTED RECEPTACLES ON THE OUTER PERIMETER OF THE CYBER SECURITY LAB. CONDUITS FEEDING RECEPTACLES SHALL BE SURFACE MOUNTED EMT.



SEAL

144 Fore Street/P.O. Box 618
 Portland, Maine 04104
 tel. (207) 772-3846
 fax. (207) 772-1070
 www.smrinc.com



ARCHITECTURE
 ENGINEERING
 PLANNING
 INTERIOR DESIGN
 COMMISSIONING



USM SCIENCE BUILDING C WING
 CYBER SECURITY LAB FIT-UP
 PROJECT 2013-007
 PORTLAND, MAINE

ISSUED FOR PERMITTING AND CONSTRUCTION
 12-20-13

CURRENT ISSUE STATUS:

REV	DESCRIPTION	DATE
0	ISSUED FOR PERMITTING AND CONSTRUCTION	12-20-13

SCALE: 1/8"=1'-0"

PROJECT MANAGER: SLB

JC/DRAWN BY: CDS

A/E OF RECORD: DJT

CAD FILE: EP101-12014-02

PROJECT NO: 12014-02

DATE: 12-20-13

SHEET TITLE:
POWER PLAN

SHEET No. **EP101**
 © COPYRIGHT 2012 SMRT INC.