

NOTE:


1. SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.

KEYED NOTES:

- ① UTILIZE AN EXISTING 20 AMP, SINGLE POLE CIRCUIT BREAKER IN PANELBOARD DP22 TO REED NEW LIGHTS.
- ② RELOCATED LIGHTS TO BE RECONNECTED TO EXISTING BRANCH CIRCUIT AND SWITCH LEGS THAT ARE CURRENTLY FEEDING AND CONTROLLING LIGHTS. SEE ED101 FOR CURRENT LIGHT LOCATIONS. CLEAN AND RELAMP FIXTURE PRIOR TO RELOCATION. ALL REMAINING LIGHT FIXTURES TO BE RETURNED TO OWNER.

ALTERNATE #4:

UNDER ALTERNATE #4 PROVIDE PRICING TO CHANGE TYPE A FIXTURES TO AN LED TYPE B FIXTURE. SEE LIGHT FIXTURE SCHEDULE ON EL601 FOR FIXTURE DESCRIPTIONS.



SEAL

144 Fore Street/P.O. Box 618
 Portland, Maine 04104
 tel. (207) 772-3846
 fax. (207) 772-1070
 www.smrinc.com



ARCHITECTURE
 ENGINEERING
 PLANNING
 INTERIOR DESIGN
 COMMISSIONING



USM SCIENCE BUILDING C WING
 CYBER SECURITY LAB FIT-UP
 PROJECT 2013-007
 PORTLAND, MAINE

ISSUED FOR PERMITTING AND CONSTRUCTION
 12-20-13

REV	DESCRIPTION	DATE
0	ISSUED FOR PERMITTING AND CONSTRUCTION	12-20-13

SCALE:	1/8"=1'-0"
PROJECT MANAGER:	SLB
JC/DRAWN BY:	CDS
A/E OF RECORD:	DJT
CAD FILE:	EL101-12014-02
PROJECT NO:	12014-02
DATE:	12-20-13

SHEET TITLE:
LIGHTING PLAN

SHEET No. **EL101**
 © COPYRIGHT 2012 SMRT INC.