

NOTES:

1. SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
2. FOR ALL DATA OUTLETS SHOWN FURNISH & INSTALL AN EMPTY DOUBLE GANG BOX WITH SINGLE GANG MUD RING AND AN EMPTY 3/4" EMT CONDUIT WITH PULL STRING TO ABOVE AN ACCESSIBLE CEILING.
3. FOR NEW FIRE ALARM NOTIFICATION DEVICE PROVIDE NEW DEVICE TO MATCH THOSE CURRENTLY INSTALLED ON THE FLOOR AND EXTEND EXISTING INITIATING CIRCUIT TO NEW DEVICE.

KEYED NOTES:

- ① EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE RELOCATED FIRE ALARM NOTIFICATION DEVICES. SEE SHEET ED101 FOR CURRENT DEVICE LOCATIONS.
- ② PROVIDE CEILING MOUNTED EMPTY OUTLET BOX AND EMPTY CONDUIT RUN TO CABLE TRAY. MOUNT BOX NEXT TO PROJECTOR RECEPTACLE. COORDINATE WITH OWNER FOR EXACT MOUNTING LOCATION FOR BOX.

144 Fore Street/P.O. Box 618
 Portland, Maine 04104
 tel. (207) 772-3846
 fax. (207) 772-1070
 www.smrtninc.com



ARCHITECTURE
 ENGINEERING
 PLANNING
 INTERIOR DESIGN
 COMMISSIONING

SMRT

USM SCIENCE BUILDING C WING
 CYBER SECURITY LAB FIT-UP
 PROJECT 2013-007
 PORTLAND, MAINE


ISSUED FOR PERMITTING AND CONSTRUCTION
 12-20-13

REV	DESCRIPTION	DATE
0	ISSUED FOR PERMITTING AND CONSTRUCTION	12-20-13

SCALE: 1/8" = 1'-0"
 PROJECT MANAGER: SLB
 JC/DRAWN BY: CDS
 A/E OF RECORD: DJT
 CAD FILE: EY101-12014-02
 PROJECT NO: 12014-02
 DATE: 12-20-13

SHEET TITLE:
SYSTEMS PLAN

SHEET No.
EY101



SEAL