

VARIABLE AIR VOLUME (VAV) TERMINAL SCHEDULE

TAG	INLET SIZE (IN)	OUTLET SIZE (IN)	SETPOINT RANGE		INLET STATIC PRESSURE-MIN.	APD MAX.	HOT WATER HEATING COIL						TYPICAL UNIT MFG & MODEL NO.	NOTES:	
			CFM MAX.	CFM MIN.			CFM	MBH	EAT (F)	LAT (F)	GPM	ROWS			WPD MAX
VAV-1	14	19X18	1340	450	0.5	0.20	660	45.5	55	85.0	1.5	1	0.6	TRANE VCWF	1

NOTES: 1. HOT WATER COIL PERFORMANCE BASED ON 180 F ENTERING WATER TEMPERATURE

REGISTER, DIFFUSER & GRILL SCHEDULE

TAG	MAX CFM	NECK SIZE	TYPE	ΔP	MAX NC	TYPICAL UNIT MFG & MODEL NO.	NOTES
S-1	50	6x6	SUPPLY	0.04	<20	PRICE 520	1
S-2	310	10"ø	SUPPLY	0.04	<20	PRICE SPD	1
R-1	50	6"ø	RETURN	0.04	<20	PRICE 530	1
R-2	620	15"ø	RETURN	0.04	<20	PRICE PDDR	1

NOTES: 1. PROVIDE BORDER FOR LAY-IN CEILING INSTALLATION, 24x24 CEILING GRID

144 Fore Street/P.O. Box 618
Portland, Maine 04104
tel. (207) 772-3846
fax. (207) 772-1070
www.smrting.com

ARCHITECTURE
ENGINEERING
PLANNING
INTERIOR DESIGN
COMMISSIONING



**USM SCIENCE BUILDING C WING
CYBER SECURITY LAB FIT-UP
PROJECT 2013-007**
PORTLAND, MAINE

ISSUED FOR PERMITTING AND CONSTRUCTION
12-20-13

REV	DESCRIPTION	DATE
0	ISSUED FOR PERMITTING AND CONSTRUCTION	12-20-13

SCALE: NONE
PROJECT MANAGER: SLB
JC/DRAWN BY: MBD
A/E OF RECORD: MJC
CAD FILE: M-003-12014-02
PROJECT NO: 12014-02
DATE: 12-20-13

SHEET TITLE:
SCHEDULES
SHEET No. **M-601**
© COPYRIGHT 2012 SMRT INC.

