



**NOTE:**

- SEE SHEET M-001 FOR LEGEND AND ABBREVIATIONS.

**KEYED NOTES:**

- THERMOSTAT AND CO2 SENSOR SHALL BE WIRED SUCH THAT ALL WIRES RUN INTERNAL TO THE SPACE. WIRES RUNNING ON THE WALL TO THERMOSTAT AND CO2 SENSOR SHALL BE HOUSED IN PLASTIC WIRE CHANNEL.
- CUT RO WATER BACK TO VALVES AND CAP. LEAVE ENOUGH PIPING TO ALLOW CAPS TO BE REMOVED IN THE FUTURE PIPING TIE-IN.



144 Fore Street/P.O. Box 618  
 Portland, Maine 04104  
 tel. (207) 772-3846  
 fax. (207) 772-1070  
 www.smrinc.com

ARCHITECTURE  
 ENGINEERING  
 PLANNING  
 INTERIOR DESIGN  
 COMMISSIONING



**USM SCIENCE BUILDING C WING  
 CYBER SECURITY LAB FIT-UP  
 PROJECT 2013-007**  
 PORTLAND, MAINE



**ISSUED FOR PERMITTING AND  
 CONSTRUCTION  
 12-20-13**

CURRENT ISSUE STATUS:

REV	DESCRIPTION	DATE
0	ISSUED FOR PERMITTING AND CONSTRUCTION	12-20-13

SCALE: 1/8" = 1'-0"

PROJECT MANAGER:	SLB
JC/DRAWN BY:	MBD
A/E OF RECORD:	MJC
CAD FILE:	MP101-12014-02
PROJECT NO:	12014-02
DATE:	12-20-13

SHEET TITLE:  
**MECHANICAL  
 PIPING PLAN**

SHEET No. **MP101**  
 © COPYRIGHT 2012 SMRT INC.