Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 7/29/2013

TECHNICAL NOTES:

1. DUCT SMOKE DETECTORS ARE IS NOTED DIAGRAMMATICALLY IN THIS SPACE. REPLACE EXISTING DUCT SMOKE DETECTOR WITH A NEW DEVICE AND CONNECT TO NEW FIRE ALARM SYSTEM. CONTRACTOR SHALL FIELD VERIFY THE EXACT LOCATION OF EACH EXISTING DETECTOR. IF 120V POWER IS REQUIRED, CONNECT TO NEARBY RECEPTACLE CIRCUIT.

AREA OF RENOVATION

KEY PLAN

REV.	DESCRIPTION	DATE
--	--	--
--	--	--
--	--	--
0	CONSTRUCTION DOCUMENTS	05.10.13

CONSTRUCTION DOCUMENTS
05.10.13

CURRENT ISSUE STATUS:

MAG. NORTH
PROJECT NORTH

STATE OF MAINE
STEPHANIE J. LAPLANT
No. 10272
LICENSED PROFESSIONAL ENGINEER
05.10.13

WBRC
ARCHITECTS• ENGINEERS
WWW.WBRCAE.COM
BANGOR, MAINE 207-947-4511
PORTLAND, MAINE 207-828-4511
SARASOTA, FLORIDA 941-556-0757

LUTHER BONNEY FIRE ALARM UPGRADES

PROJECT: PORTLAND, MAINE

THIRD FLOOR FIRE ALARM PLAN - SEG B

SHEET TITLE:

WBRC CAD FILE: 3842.13 – FA103B

PROJECT No. 3842.13

GRAPHIC SCALE: 0" 1"

SCALE: AS NOTED

PM: SJL

DRAWN BY: KRM

A/E OF RECORD: SJL

SHEET No. FA103B

© COPYRIGHT 2013 WBRC

A1	THIRD FLOOR FIRE ALARM PLAN - SEG B
1/8" = 1'-0"	--

6/3/2013 9:46 AM I:\3801-3900\384210 USM FIRE ALARM SYSTEM UPGRADES\2 DESIGN\DWGS\BLDG\LUTHER BONNEY 6P002\BONNEY LUTHER FIRE ALARM UPGRADES\SHEETS\3842.13-FA103B THIRD FLOOR FIRE ALARM PLAN - SEG B.DWG KYLE.MAHAR