

6/3/2013 10:09 AM I:\3801-3900\384210 USM FIRE ALARM SYSTEM UPGRADES\2 DESIGN\DWGS\BLOC\MASTERON_6P035\MASTERON_HALL_FIRE_ALARM_UPGRADE\SHEETS\3842.11-FA103 THIRD FLOOR FIRE ALARM PLAN.DWG KYLE MAHAR




- TECHNICAL NOTES:**
- ① MAINTAIN EXISTING FLOW AND TAMPER SWITCHES AND OTHER SPRINKLER SYSTEM DEVICE CONNECTIONS.
 - ② RELEASE OF EXISTING SMOKE HATCH SHALL BE INITIATED BY ADJACENT SMOKE DETECTOR ONLY.
 - ③ PROVIDE DOOR CONTACT/POSITION SWITCH AT ROOF HATCH & CONNECT TO FIRE ALARM SYSTEM VIA A MONITOR MODULE. SYSTEM TO RECEIVE A SUPERVISORY SIGNAL WHEN ROOF HATCH IS IN THE OPEN POSITION.


0	CONSTRUCTION DOCUMENTS	05.10.13
REV.	DESCRIPTION	DATE

CONSTRUCTION DOCUMENTS
05.10.13

CURRENT ISSUE STATUS:



PROJECT NORTH



STEPHANIE L. LAPLANT
No. 10272
LICENSED PROFESSIONAL ENGINEER

WBRC
ARCHITECTS • ENGINEERS
www.wbrcae.com
BANGOR, MAINE 207-947-4511
PORTLAND, MAINE 207-628-4511
SARASOTA, FLORIDA 941-556-0757

MASTERON HALL FIRE ALARM UPGRADE

PROJECT: PORTLAND, MAINE

THIRD FLOOR FIRE ALARM PLAN

WBRC CAD FILE:	3842.11 - FA103
PROJECT No.	3842.11
SCALE:	AS NOTED
PM:	SJL
DRAWN BY:	KRM
A/E OF RECORD:	SJL
GRAPHIC SCALE:	0" = 1"
SHEET No.	FA103

A1 **THIRD FLOOR FIRE ALARM PLAN**

1/8" = 1'-0"