

<input type="checkbox"/> 1 - Reviewed, No Exception Taken	
<input type="checkbox"/> 2 - Reviewed, Revise as Noted	
<input checked="" type="checkbox"/> 3 - Revise and Resubmit	
<input type="checkbox"/> 4 - Rejected	
<input type="checkbox"/> 5 - Other, Held for Record, Not Reviewed	
<p>This review is only for general conformance with the design concept and the information given in the Contract Documents. Corrections or comments made on the shop drawings during this review do not relieve the Contractor from compliance with the requirements of the Contract Documents and applicable laws, codes and regulations. Review of a specific item shall not include review of an assembly of which the item is a component. The Contractor is responsible for: dimensions to be confirmed and correlated at the jobsite; information that pertains solely to the fabrication; processes, means, methods, techniques, sequences and procedures of construction; coordination of the Work with that of all trades and performing all Work in a safe and satisfactory manner.</p>	
REVIEWER: SJL	DATE: 06.23.13

# University of Southern Maine Masterton Building Fire Alarm System Replacement Portland, ME

**Comments:**

Notification devices submitted as red. Provide white devices as specified.

**Prepared For:**

**TRT Electric  
65 Washington Street  
Augusta, ME 04330**

**Presented By:**

 **NOTIFIER®**  
**BK Systems, Inc.**  
**4 Cote Avenue**  
**Goffstown, NH 03045**  
**Telephone: (603) 647-8775**  
**Fax: (603) 647-4806**  
**Ricky Houde**