Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 7/29/2013

TECHNICAL NOTES:

1. MAINTAIN EXISTING FLOW AND TAMPER SWITCHES AND OTHER SPRINKLER SYSTEM DEVICE CONNECTIONS.

REV.	DESCRIPTION	DATE
--	--	--
--	--	--
--	--	--
0	CONSTRUCTION DOCUMENTS	05.10.13

CONSTRUCTION DOCUMENTS
05.10.13

CURRENT ISSUE STATUS:

MAG. NORTH
PROJECT NORTH

STATE OF MAINE
STEPHANIE J. LAPLANT
No. 10272
LICENSED PROFESSIONAL ENGINEER
05.10.13

WBRC
ARCHITECTS• ENGINEERS
WWW.WBRCAE.COM
BANGOR, MAINE 207-947-4511
PORTLAND, MAINE 207-828-4511
SARASOTA, FLORIDA 941-556-0757

MASTERTON HALL FIRE ALARM UPGRADE

PROJECT: PORTLAND, MAINE

SECOND FLOOR FIRE ALARM PLAN

SHEET TITLE:

WBRC CAD FILE: 3842.11 – FA102

PROJECT No. 3842.11

GRAPHIC SCALE: 0" 1"

SCALE: AS NOTED

PM: SJL

DRAWN BY: KRM

A/E OF RECORD: SJL

SHEET No. FA102

© COPYRIGHT 2013 WBRC

A1	SECOND FLOOR FIRE ALARM PLAN
1/8" = 1'-0"	--

6/3/2013 10:08 AM I:\3801-3900\384210 USM FIRE ALARM SYSTEM UPGRADES\2 DESIGN\DWGS\BLDG\MASTERTON 6F035\MASTERSON HALL FIRE ALARM UPGRADE\SHEETS\3842.11-FA102 SECOND FLOOR FIRE ALARM PLAN.DWG KYLE.MAHAR