☐ 1 - Reviewed, No Exception Taken
☐ 2 - Reviewed, Revise as Noted
☒ 3 - Revise and Resubmit
☐ 4 - Rejected
☐ 5 - Other, Held for Record, Not Reviewed

WBRC ARCHITECTS • ENGINEERS

This review is only for general conformance with the design concept and the information given in the Contract Documents. Corrections or comments made on the shop drawings during this review do not relieve the Contractor from compliance with the requirements of the Contract Documents and applicable laws, codes and regulations. Review of a specific item shall not include review of an assembly of which the item is a component. The Contractor is responsible for: dimensions to be confirmed and correlated at the jobsite; information that pertains solely to the fabrication; processes, means, methods, techniques, sequences and procedures of construction; coordination of the Work with that of all trades and performing all Work in a safe and satisfactory manner.

REVIEWER: SJL DATE: 06.23.13

RESURGAM CITY OF PORTLAND, MAINE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/29/13

University of Southern Maine
Masterton Building
Fire Alarm System Replacement
Portland, ME

Comments:

Notification devices submitted as red. Provide white devices as specified.

Prepared For:

TRT Electric
65 Washington Street
Augusta, ME 04330

NOTIFIER®

Presented By:

BK Systems, Inc.
4 Cote Avenue
Goffstown, NH 03045
Telephone: (603) 647-8775
Fax: (603) 647-4806
Ricky Houde