Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 7/29/2013

TECHNICAL NOTES:

1. MAINTAIN EXISTING FLOW AND TAMPER SWITCHES AND OTHER SPRINKLER SYSTEM DEVICE CONNECTIONS.
2. RELEASE OF EXISTING SMOKE HATCH SHALL BE INITIATED BY ADJACENT SMOKE DETECTOR ONLY.
3. PROVIDE DOOR CONTACT/POSITION SWITCH AT ROOF HATCH & CONNECT TO FIRE ALARM SYSTEM VIA A MONITOR MODULE. SYSTEM TO RECEIVE A SUPERVISORY SIGNAL WHEN ROOF HATCH IS IN THE OPEN POSITION.

REV.	DESCRIPTION	DATE
--	--	--
--	--	--
--	--	--
0	CONSTRUCTION DOCUMENTS	05.10.13

CONSTRUCTION DOCUMENTS
05.10.13

CURRENT ISSUE STATUS:

MAG. NORTH
PROJECT NORTH

STATE OF MAINE
STEPHANIE A. LAPLANT
No. 10272
LICENSED PROFESSIONAL ENGINEER
05.10.13

WBRC
ARCHITECTS• ENGINEERS
WWW.WBRCAE.COM
BANGOR, MAINE 207-947-4511
PORTLAND, MAINE 207-828-4511
SARASOTA, FLORIDA 941-556-0757

MASTERTON HALL FIRE ALARM UPGRADE

PROJECT: PORTLAND, MAINE

THIRD FLOOR FIRE ALARM PLAN

SHEET TITLE:

WBRC CAD FILE:	3842.11 – FA103
PROJECT No.	3842.11
SCALE:	AS NOTED
PM:	SJL
DRAWN BY:	KRM
A/E OF RECORD:	SJL

GRAPHIC SCALE: 0" 1"

SHEET No. FA103

© COPYRIGHT 2013 WBRC

A1	THIRD FLOOR FIRE ALARM PLAN
1/8" = 1'-0"	--

6/3/2013 10:09 AM I:\3801-3900\384210 USM FIRE ALARM SYSTEM UPGRADES\2 DESIGN\DWGS\BLDG\MASTERTON 6P035\MASTERSON HALL FIRE ALARM UPGRADE\SHEETS\3842.11-FA103 THIRD FLOOR FIRE ALARM PLAN.DWG KYLE.MAHAR