

6/3/2013 9:57 AM I:\3801-3900\384210 USM FIRE ALARM SYSTEM UPGRADES\DESIGN\DWGS\BLDG\PAYSON SMITH FIRE ALARM UPGRADES\SHEETS\3842.12-FA101 FIRST FLOOR FIRE ALARM PLAN.DWG KYLE MAHAR



TECHNICAL NOTES:

- (1) OBTAIN POWER FROM AVAILABLE 120V CIRCUIT WITHIN BOILER ROOM 024 OR POWER CLOSET 004A.
- (2) FIELD LOCATE WITHIN THIS ROOM.
- (3) EXISTING PIPE CHASE ACCESSIBLE AT ALL LEVELS.
- (4) EXISTING CONDUITS WITH ABANDONED CABLES, ACCESSIBLE AT ALL LEVELS.
- (5) PROVIDE RECEPTACLE ADJACENT TO CITY BOX FEED POWER FROM NEARBY RECEPTACLE CIRCUIT. ANTENNA SHALL BE ROOF MOUNTED.

REV.	DESCRIPTION	DATE
1	ADDENDUM #1	05.28.13
0	CONSTRUCTION DOCUMENTS	05.10.13

CONSTRUCTION DOCUMENTS
05.10.13

CURRENT ISSUE STATUS:

WBRC
ARCHITECTS • ENGINEERS
WWW.WBRCAE.COM
BANGOR, MAINE 207-947-4511
PORTLAND, MAINE 207-628-4511
SARASOTA, FLORIDA 941-556-0757

PAYSON SMITH FIRE ALARM UPGRADES

PROJECT: PORTLAND, MAINE
FIRST FLOOR FIRE ALARM PLAN

SHEET TITLE:	3842.12 - FA101	
WBRC CAD FILE:	3842.12	GRAPHIC SCALE: 0" = 1'
PROJECT No.:	AS NOTED	
SCALE:	SJL	
PM:	KRM	SHEET No. FA101
DRAWN BY:	SJL	
A/E OF RECORD:		

A1 **FIRST FLOOR FIRE ALARM PLAN**

1/8" = 1'-0"