



- NOTES**
1. PROVIDE MANUAL AIR VENTS AT ALL SYSTEM HIGH POINTS.
  2. PIPING SHALL BE INSTALLED TO AVOID 90°-LESS THAN 6" PIPE DIAMETERS

**1 REVERSE OSMOSIS FLOW DIAGRAM**

SCALE: N.T.S.

OWNER REVIEW	DATE

NO.	DATE	DESCRIPTION
06.21.08	ISSUED FOR CONSTRUCTION	
06.03.08	SCORE REVISION	
A	03.27.08	100% QC REVIEW
NO.	DATE	DESCRIPTION
ISSUE NO.		

UNIVERSITY OF  
SOUTHERN MAINE  
70 FALMOUTH STREET  
PORTLAND, MAINE

RESEARCH WING  
PHASE III FIT-OUT

PROCESS  
FLOW DIAGRAM  
No. 1

SCALE	NTS
DRAWN BY	MWR
CHECKED BY	
PROJ. MGR./ ENGR.	TCW
PROJ. MGR.	RCH
JOB NO.	03048110
© SYMES, MAINT & MCKEE ASSOCIATES, INC. 2004	