

Oakhurst Dairy – New Milk Cooler

SECTION 15122 - METERS AND GAGES**PART 1 - GENERAL****1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes the following meters and gages for mechanical systems:
 - 1. Thermometers.
 - 2. Gages.
 - 3. Test plugs.
- B. Related Sections include the following:
 - 1. Division 15 Section "Domestic Water Piping" for domestic and fire-protection water service meters inside the building.

1.3 DEFINITIONS

- A. CR: Chlorosulfonated polyethylene synthetic rubber.
- B. EPDM: Ethylene-propylene-diene terpolymer rubber.

1.4 SUBMITTALS

- A. Product Data: For each type of product indicated; include performance curves.
- B. Shop Drawings: Schedule for thermometers, gages indicating manufacturer's number, scale range, and location for each.

PART 2 - PRODUCTS**2.1 MANUFACTURERS**

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
 - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, manufacturers specified.
 - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the manufacturers specified.

2.2 PRESSURE GAGES

- A. Manufacturers:
 - 1. AMETEK, Inc.; U.S. Gauge Div.
 - 2. Ashcroft Commercial Instrument Operations; Dresser Industries; Instrument Div.

Oakhurst Dairy – New Milk Cooler

3. Ernst Gage Co.
 4. Eugene Ernst Products Co.
 5. KOBOLD Instruments, Inc.
 6. Marsh Bellofram.
 7. Miljoco Corp.
 8. Noshok, Inc.
 9. Palmer - Wahl Instruments Inc.
 10. REO TEMP Instrument Corporation.
 11. Trerice, H. O. Co.
 12. Weiss Instruments, Inc.
 13. Weksler Instruments Operating Unit; Dresser Industries; Instrument Div.
 14. WIKA Instrument Corporation.
 15. Winters Instruments.
- B. Direct-Mounting, Dial-Type Pressure Gages: Indicating-dial type complying with ASME B40.100.
1. Case: Liquid-filled type, drawn steel or cast aluminum 4-1/2-inch diameter.
 2. Pressure-Element Assembly: Bourdon tube, unless otherwise indicated.
 3. Pressure Connection: Brass, NPS 1/4, bottom-outlet type unless back-outlet type is indicated.
 4. Movement: Mechanical, with link to pressure element and connection to pointer.
 5. Dial: Satin-faced, nonreflective aluminum with permanently etched scale markings.
 6. Pointer: Red metal.
 7. Window: Plastic.
 8. Ring: Brass.
 9. Accuracy: Grade B, plus or minus 2 percent of middle half scale.
 10. Vacuum-Pressure Range: 30-in. Hg of vacuum to 15 psig of pressure.
 11. Range for Fluids under Pressure: Two times operating pressure.
- C. Pressure-Gage Fittings:
1. Valves: NPS 1/4 brass or stainless-steel needle type.
 2. Syphons: NPS 1/4 coil of brass tubing with threaded ends.
 3. Snubbers: ASME B40.5, NPS 1/4 brass bushing with corrosion-resistant, porous-metal disc of material suitable for system fluid and working pressure.

PART 3 - EXECUTION**3.1 GENERAL**

- A. Provide pressure gauge applications at domestic water service entrance before and after back flow preventer.

Oakhurst Dairy – New Milk Cooler**3.2 INSTALLATIONS**

- A. Install direct-mounting pressure gages in piping tees with pressure gage located on pipe at most readable position.
- B. Install needle-valve and snubber fitting in piping for each pressure gage for fluids (except steam).

3.3 CONNECTIONS

- A. Install meters and gages adjacent to machines and equipment to allow service and maintenance for meters, gages, machines, and equipment.

3.4 ADJUSTING

- A. Calibrate meters according to manufacturer's written instructions, after installation.
- B. Adjust faces of meters and gages to proper angle for best visibility.

END OF SECTION 15122