



Certificate of Occupancy

CITY OF PORTLAND, MAINE

Department of Planning and Urban Development Building Inspections Division



Location: 18 Durham St

CBL: 114A G006001

Issued To: UNIVERSITY OF MAINE

Issued Date: 09/03/2015

This is to certify that the building, premises, or part thereof, at the above location, built-altered-changed as to use under Building Permit No. 201402890 has had a final inspection, has been found to conform substantially to the requirements of the Building Code and the Land Use Code of the City of Portland, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY ZONING

APPROVED OCCUPANCY BUILDING

Entire

State University

Utility - Central Heat Plant

Occupant Load = 16

Building is not sprinkled

Use Group Utility

Type IIB

MUBEC/IBC 2009

LIMITING CONDITIONS:

Approved: /S/ Brian LaFlamme

Inspector

Inspection Division Director

Notice: This certificate identifies the legal use of the building or premises, and ought to be transferred from owner to owner upon the sale of the property.