

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT

This is to certify that  
RESIDENTIAL FIRE PROTECTION LLC  
64 DAGGETT HILL RD  
GREENE, ME 04236

For installation at  
23 BEDFORD ST  
USM MAINTENANCE BUILDING


Job ID: 2012-04-3694-ALTCOMM

CBL: 114A-G-009-001

has permission to install NFPA 13 automatic sprinkler system provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be

  
Fire Prevention Officer

58

Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
PENALTY FOR REMOVING THIS CARD



# PORTLAND MAINE

*Strengthening a Remarkable City, Building a Community for Life • [www.portlandmaine.gov](http://www.portlandmaine.gov)*

Director of Planning and Urban Development  
Penny St. Louis

**Job ID: 2012-04-3694-ALTCOMM  
install NFPA 13 automatic sprinkler  
system**

**For installation at:  
23 BEDFORD ST  
USM MAINTENANCE BUILDING**

**CBL: 114A- G-009-001**

## **Conditions of Approval:**

### **Fire**

Installation shall be in accordance with NFPA 13. A signed compliance letter will be required.

A separate sprinkler permit is required from the State Fire Marshal's Office.

If the building has a fire alarm system, sprinkler supervision shall be provided in accordance with NFPA 101, *Life Safety Code*, and NFPA 72, *National Fire Alarm and Signaling Code*.

Sprinkler protection shall be maintained. Where the system is to be shut down for maintenance or repair, the system shall be checked at the end of each day to insure the system has been placed back in service.

The Fire Department will require Knox locking caps on all Fire Department Connections on the exterior of the building.

System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.

A Knox Box is required.

Private fire mains and fire hydrants shall be maintained, tested and painted in accordance with City Code Chapter 10, Art IV and Chapter 2 of the Fire Department Rules and Regulations.

**City of Portland, Maine - Building or Use Permit Application**

389 Congress Street, 04101 Tel: (207) 874-8703, FAX: (207) 8716

Job No: 2012-04-3694-ALTCOMM 2012-44731 FAFS	Date Applied: 6/7/2012	CBL: 114A- G-009-001	
Location of Construction: 23 BEDFORD ST	Owner Name: UNIVERSITY OF MAINE	Owner Address: 107 MAINE AVE BANGOR, ME 04401	Phone:
Business Name: USM maintenance Bldg	Contractor Name: RESIDENTIAL FIRE PROTECTION	Contractor Address: 64 DAGGETT HILL ROAD, GREENE, ME 04236	Phone: (207) -946-3473
Lessee/Buyer's Name:	Phone:	Permit Type: FAFS	Zone: B-2 & USM OVERLAY
Past Use: USM Maintenance Bldg	Proposed Use: Same: USM Maintenance Bldg – to install fire suppression system	Cost of Work: \$24,000.00	CEO District:
		Fire Dept: 6/14/12 <input checked="" type="checkbox"/> Approved w/ conditions <input type="checkbox"/> Denied <input type="checkbox"/> N/A	Inspection: Use Group: Type:
		Signature: <i>Bjorn Wald</i> (58)	Signature:
Proposed Project Description: install fire suppression system		Pedestrian Activities District (P.A.D.)	
Permit Taken By: Brad		<b>Zoning Approval</b>	

<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building Permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False informatin may invalidate a building permit and stop all work.</p>	<p><b>Special Zone or Reviews</b></p> <p><input type="checkbox"/> Shoreland</p> <p><input type="checkbox"/> Wetlands</p> <p><input type="checkbox"/> Flood Zone</p> <p><input type="checkbox"/> Subdivision</p> <p><input type="checkbox"/> Site Plan</p> <p>___ Maj ___ Min ___ MM</p> <p>Date: <i>OK</i> 6/10/12</p>	<p><b>Zoning Appeal</b></p> <p><input type="checkbox"/> Variance</p> <p><input type="checkbox"/> Miscellaneous</p> <p><input type="checkbox"/> Conditional Use</p> <p><input type="checkbox"/> Interpretation</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Denied</p> <p>Date:</p>	<p><b>Historic Preservation</b></p> <p><input checked="" type="checkbox"/> Not in Dist or Landmark</p> <p><input type="checkbox"/> Does not Require Review</p> <p><input type="checkbox"/> Requires Review</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Approved w/Conditions</p> <p><input type="checkbox"/> Denied</p> <p>Date: <i>S</i></p>
	<b>CERTIFICATION</b>		

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT ADDRESS DATE PHONE

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE DATE PHONE



# Water-Based Fire Suppression System Permit

Entered 6/7/12  
133

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Parent #: 2012-04-3654 - Altcomm

Installation address: <sup>23</sup> 25 Bedford St. 2012-44731 CBL: INA 6009

Exact location: (within structure) Entire Building

Type of occupancy(s) (NFPA & ICC): Offices/Maintenance shop USM

Building owner: USM overlay

Managing Supervisor (RMS): Stan Camic License No: 80 B-2

Supervisor phone: 207-713-5912 E-mail: scamic@rfpllc.net

Installing contractor: Residential Fire Protection License No: 511

Contractor phone: 207-946-3473 E-mail: scamic@rfpllc.net

The suppression work to be done will be: New:  Renovation:  Addition to existing system:

This is an amendment to an existing permit: Yes:  NO:  Permit no: \_\_\_\_\_

NFPA Standard this system is designed to: 13 Edition: 3010

\*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from [www.portlandmaine.gov/fire](http://www.portlandmaine.gov/fire) for every submittal. Attach all working documents and complete approved submittals as may be required by the State Fire Marshal's Office on electronic PDF's in addition to full sized plans.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

**COST OF WORK:** 23,230.00

**PERMIT FEE:** 260.00

(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

**RECEIVED**

**JUN 07 2012**

Dept. of Building Inspections  
City of Portland Maine

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

Applicant signature: Date: 6-5-12



# PORTLAND MAINE

*Strengthening a Remarkable City, Building a Community for Life • [www.portlandmaine.gov](http://www.portlandmaine.gov)*

## Receipts Details:

**Tender Information:** Check , Check Number: 3549

**Tender Amount:** 260.00

## Receipt Header:

**Cashier Id:** bsaucier

**Receipt Date:** 6/7/2012

**Receipt Number:** 44732

## Receipt Details:

Referance ID:	6807	Fee Type:	BP-FIRE
Receipt Number:	0	Payment Date:	
Transaction Amount:	260.00	Charge Amount:	260.00
Job ID: Job ID: 2012-04-3694-ALTCOMM - Interior Renovations/ Floor plan reconfiguration			
Additional Comments: 23 (25) Bedford			

Thank You for your Payment!



**State of Maine**  
**Department of Public Safety**  
**Fire Sprinkler System Permit**



# 10039

**USM 25 Bedford St. Renovation**

Located at: 25 Bedford St.  
 In the Town of: Portland  
 Occupancy/Use: Office/Maintenance facility  
 Type of System: NFPA 13

Permission is hereby given to:

**Residential Fire Protection LLC**

64 Daggett Hill Road  
 Greene, ME 04236  
 Contractor License # 511

to begin installation according to plans submittal approved by the Office of State Fire Marshal.  
 The submittal is filed under log # 2121238 , and no departure from the application submittal shall be made without prior approval in writing. This permit is issued under the provisions of Title 32, Chapter 20, Section 12004-I. Nothing herein shall excuse the holder of this permit from failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions. This permit shall be displayed at the construction site or be made readily available.

This permit was issued on 6/7/2012 for a fee paid of \$177.00  
 This permit will expire at midnight on Tuesday, December 04, 2012

The expiration date applies only if the installation has not begun by that date and no permission has been granted to extend the date. Once installation begins, then the permit is valid for however long it takes to complete the installation, assuming that the work is fairly continuous.

*John E Morris*  
 John E. Morris  
 Commissioner

***The type of Fire Department Connection and its location is to be according to the Local Fire Department***

Within 30 days of the completion of a new fire sprinkler system or an addition to an existing fire sprinkler system, a fire sprinkler system contractor shall provide to the Office of State Fire Marshal a copy of this permit signed and dated by the certified Responsible Managing Supervisor representing that the fire sprinkler system has been installed according to specifications of the approved plan to the best of the supervisor's knowledge, information, and belief. This requirement is part of the sprinkler law, and neglect of this duty is grounds to not renew the contractor's license to do work in the State of Maine. All renewed sprinkler licenses are good for two years and expire on a June 30th.

Job completed, tested and verified by date of \_\_\_\_\_

RMS for this job: Camic Stan

RMS Signature: \_\_\_\_\_

Hydraulic Design Information Sheet

Name - USM 25 Bedford St. Date - 6-1-12  
Location - Above ceiling  
Building - System No. - 1 of 1  
Contractor - Residential Fire Protection Contract No. - C12017  
Calculated By - JAL Drawing No. - 1 of 1  
Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - 12'-9"  
Occupancy - Unoccupied concealed space

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other

T Specific Ruling Made By Date

E  
M Area of Sprinkler Operation - 1500 System Type Sprinkler/Nozzle  
Density - .1 (X) Wet Make Victaulic  
D Area Per Sprinkler - 130 ( ) Dry Model V2704  
E Elevation at Highest Outlet - 19.75 ( ) Deluge Size 1/2"  
S Hose Allowance - Inside - ( ) Preaction K-Factor 5.6  
I Rack Sprinkler Allowance - ( ) Other Temp.Rat.200  
G Hose Allowance - Outside - 100

N Note Safety Margin: 63.373

Calculation Flow Required - 307.163 Press Required - 39.060  
Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - 8-23-07 Cap. -  
T Time of Test - Rated Cap.- Elev.-  
E Static Press - 104 @ Press -  
R Residual Press - 20 Elev. - Well  
Flow - 2642 Proof Flow  
S Elevation - 0

U Location -

P Source of Information -  
L  
Y

C Commodity Class Location  
O Storage Ht. Area Aisle W.  
M Storage Method: Solid Piled % Palletized % Rack  
M  
S R ( ) Single Row ( ) Conven. Pallet ( ) Auto. Storage ( ) Encap.  
T A ( ) Double Row ( ) Slave Pallet ( ) Solid Shelf ( ) Non  
O C ( ) Mult. Row ( ) Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling  
A Longitudinal Transverse

G Horizontal Barriers Provided:  
E

# Water Supply Curve (C)

RESIDENTIAL FIRE PROTECTION  
USM 25 Bedford St. Renovation


Page 2  
Date 06-01-12

### City Water Supply:

C1 - Static Pressure : 104  
C2 - Residual Pressure: 20  
C2 - Residual Flow : 2642

### Demand:

D1 - Elevation : \_\_\_\_\_  
D2 - System Flow : 207.163  
D2 - System Pressure : 39.060  
Hose ( Adj City ) : \_\_\_\_\_  
Hose ( Demand ) : 100  
D3 - System Demand : 307.163  
Safety Margin : 63.372





# Fittings Used Summary

RESIDENTIAL FIRE PROTECTION  
USM 25 Bedford St. Renovation

Page 3  
Date 06-01-12

Fitting Legend		½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24	
Abbrev.	Name																					
E	90° Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
G	Generic Gate Valve	0	0	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
T	90° Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
Zac	Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																				

# Pressure / Flow Summary - STANDARD

RESIDENTIAL FIRE PROTECTION  
USM 25 Bedford St. Renovation

Page 4  
Date 06-01-12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
HD1	19.75	5.6	7.0	na	14.82	0.1	130	7.0
1	0.0	K = K @ SPG1	16.08	na	14.82			
2	0.0	K = K @ SPG1	16.82	na	15.16			
3	0.0	K = K @ SPG1	19.3	na	16.23			
4	0.0	K = K @ SPG1	24.81	na	18.41			
5	0.0	K = K @ SPG1	27.31	na	19.31			
6	0.0	K = K @ SPG1	16.13	na	14.84			
7	0.0	K = K @ SPG1	16.88	na	15.18			
8	0.0	K = K @ SPG1	19.37	na	16.26			
9	0.0	K = K @ SPG1	24.9	na	18.44			
10	0.0	K = K @ SPG1	27.4	na	19.34			
11	0.0	K = K @ SPG1	28.45	na	19.71			
12	0.0	K = K @ SPG1	27.74	na	19.46			
20	0.0		28.41	na				
21	0.0		28.5	na				
22	0.0		28.85	na				
23	6.5		30.2	na				
TR	0.0		35.08	na				
BR	0.0		37.92	na	100.0			
TEST	0.0		39.06	na				

The maximum velocity is 17.18 and it occurs in the pipe between nodes 8 and 9

# Final Calculations - Hazen-Williams

RESIDENTIAL FIRE PROTECTION  
USM 25 Bedford St. Renovation

Page 5  
Date 06-01-12

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
HD1	14.82	1.049	1T	5.0	2.000	7.000			K Factor = 5.60	
to		120		0.0	5.000	8.554				
SPG1	14.82	0.0747		0.0	7.000	0.523			Vel = 5.50	
	0.0									
	14.82					16.077			K Factor = 3.70	
1	14.82	1.049		0.0	10.000	16.077			K Factor @ node SPG1	
to		120		0.0	0.0	0.0				
2	14.82	0.0747		0.0	10.000	0.747			Vel = 5.50	
2	15.15	1.049		0.0	9.000	16.824			K Factor @ node SPG1	
to		120		0.0	0.0	0.0				
3	29.97	0.2750		0.0	9.000	2.475			Vel = 11.13	
3	16.24	1.049		0.0	9.000	19.299			K Factor @ node SPG1	
to		120		0.0	0.0	0.0				
4	46.21	0.6126		0.0	9.000	5.513			Vel = 17.15	
4	18.40	1.38	1T	6.0	6.000	24.812			K Factor @ node SPG1	
to		120		0.0	6.000	0.0				
20	64.61	0.2997		0.0	12.000	3.596			Vel = 13.86	
	0.0									
	64.61					28.408			K Factor = 12.12	
5	19.31	1.049	1T	5.0	4.000	27.310			K Factor @ node SPG1	
to		120		0.0	5.000	0.0				
20	19.31	0.1220		0.0	9.000	1.098			Vel = 7.17	
	0.0									
	19.31					28.408			K Factor = 3.62	
6	14.84	1.049		0.0	10.000	16.133			K Factor @ node SPG1	
to		120		0.0	0.0	0.0				
7	14.84	0.0749		0.0	10.000	0.749			Vel = 5.51	
7	15.19	1.049		0.0	9.000	16.882			K Factor @ node SPG1	
to		120		0.0	0.0	0.0				
8	30.03	0.2760		0.0	9.000	2.484			Vel = 11.15	
8	16.26	1.049		0.0	9.000	19.366			K Factor @ node SPG1	
to		120		0.0	0.0	0.0				
9	46.29	0.6146		0.0	9.000	5.531			Vel = 17.18	
9	18.43	1.38	1T	6.0	6.000	24.897			K Factor @ node SPG1	
to		120		0.0	6.000	0.0				
21	64.72	0.3006		0.0	12.000	3.607			Vel = 13.88	
	0.0									
	64.72					28.504			K Factor = 12.12	
10	19.34	1.049	1T	5.0	4.000	27.403			K Factor @ node SPG1	
to		120		0.0	5.000	0.0				
21	19.34	0.1223		0.0	9.000	1.101			Vel = 7.18	
	0.0									
	19.34					28.504			K Factor = 3.62	
11	19.71	1.38	1T	6.0	6.000	28.451			K Factor @ node SPG1	
to		120		0.0	6.000	0.0				
22	19.71	0.0332		0.0	12.000	0.399			Vel = 4.23	
	0.0									
	19.71					28.850			K Factor = 3.67	

Final Calculations - Standard

RESIDENTIAL FIRE PROTECTION  
USM 25 Bedford St. Renovation

Page 6  
Date 06-01-12

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
12 to 22	19.46  19.46	1.049 120 0.1237	1T  5.0 0.0 0.0	4.000 5.000 9.000	27.737 0.0 1.113		K Factor @ node SPG1  Vel = 7.22		
	0.0 19.46					28.850	K Factor = 3.62		
20 to 21	83.92  83.92	3.26 120 0.0074	  0.0 0.0 0.0	13.000 0.0 13.000	28.408 0.0 0.096		Vel = 3.23		
21 to 22	84.07  167.99	3.26 120 0.0266	  0.0 0.0 0.0	13.000 0.0 13.000	28.504 0.0 0.346		Vel = 6.46		
22 to 23	39.17  207.16	3.26 120 0.0393	2E 18.815 1T 20.159 0.0	66.875 38.974 105.849	28.850 -2.815 4.161		Vel = 7.96		
23 to TR	0.0  207.16	3.26 120 0.0393	3E 28.223  0.0	24.500 28.223 52.723	30.196 2.815 2.072		Vel = 7.96		
TR to BR	0.0  207.16	3.26 120 0.0393	1Zac 0.0 1Z 9.408 0.0	5.000 9.408 14.408	35.083 2.268 0.566		* Fixed loss = 2.268 Vel = 7.96		
BR to TEST	100.00  307.16	4.1 140 0.0201	1G 2.907 1T 29.067 0.0	25.000 31.974 56.974	37.917 0.0 1.143		Qa = 100 Vel = 7.46		
	0.0 307.16					39.060	K Factor = 49.15		

Hydraulic Design Information Sheet

Name - USM 25 Bedford St. Date - 6-1-12  
 Location - Maintenance Shop  
 Building - System No. - 1 of 1  
 Contractor - Residential Fire Protection Contract No. - C12017  
 Calculated By - JAL Drawing No. - 1 of 1  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - 12'-9"  
 Occupancy - Maintenance shop

S (X) NFPA 13 ( ) Lt. Haz. Ord.Haz.Gp. ( ) 1 (X) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 1500	System Type	Sprinkler/Nozzle
	Density	- .20	(X) Wet	Make Victaulic
D	Area Per Sprinkler	- 130	( ) Dry	Model V2704
E	Elevation at Highest Outlet	- 17.800	( ) Deluge	Size 1/2"
S	Hose Allowance - Inside	-	( ) Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	-	( ) Other	Temp.Rat.155
G	Hose Allowance - Outside	- 100		

Note Safety Margin: 24.338

Calculation Flow Required - 626.880 Press Required - 73.793  
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 8-23-07		Cap. -
T	Time of Test -	Rated Cap.-	Elev.-
E	Static Press - 104	@ Press -	
R	Residual Press - 20	Elev. -	Well
	Flow - 2642		Proof Flow
S	Elevation - 0		

U Location -

P

L Source of Information -

Y

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S R	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T A	( ) Mult. Row		( ) Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

G

E Horizontal Barriers Provided:

# Water Supply Curve (C)


RESIDENTIAL FIRE PROTECTION  
USM Shop AREA

### City Water Supply:

C1 - Static Pressure : 104  
C2 - Residual Pressure: 20  
C2 - Residual Flow : 2642

### Demand:

D1 - Elevation : 7.709  
D2 - System Flow : 376.88  
D2 - System Pressure : 73.794  
Hose ( Adj City ) : \_\_\_\_\_  
Hose ( Demand ) : 250  
D3 - System Demand : 626.88  
Safety Margin : 24.338



# Fittings Used Summary

RESIDENTIAL FIRE PROTECTION  
USM Shop AREA

Page 3  
Date 06-01-12

Fitting Legend		½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Zac	Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																			

# Pressure / Flow Summary - STANDARD

RESIDENTIAL FIRE PROTECTION  
USM Shop AREA

Page 4  
Date 06-01-12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	17.8	5.6	21.56	na	26.0	0.2	130	7.0
2	17.8	5.6	23.67	na	27.25	0.2	130	7.0
3	17.8	5.6	30.84	na	31.1	0.2	130	7.0
4	17.8	5.6	35.74	na	33.48	0.2	130	7.0
5	17.8	5.6	38.14	na	34.58	0.2	130	7.0
6	17.8	5.6	21.71	na	26.09	0.2	130	7.0
7	17.8	5.6	23.84	na	27.34	0.2	130	7.0
8	17.8	5.6	31.06	na	31.21	0.2	130	7.0
9	17.8	5.6	35.99	na	33.6	0.2	130	7.0
10	17.8	5.6	38.41	na	34.7	0.2	130	7.0
11	17.8	5.6	42.22	na	36.39	0.2	130	7.0
12	17.8	5.6	39.37	na	35.14	0.2	130	7.0
20	0.0		49.25	na				
21	0.0		49.54	na				
22	0.0		50.59	na				
23	0.0		59.77	na				
TR	0.0		66.04	na				
BR	0.0		71.79	na				
UG1	0.0		73.46	na	250.0			
TEST	0.0		73.79	na				

The maximum velocity is 19.84 and it occurs in the pipe between nodes 7 and 8



# Final Calculations - Hazen-Williams

RESIDENTIAL FIRE PROTECTION  
USM Shop AREA

Page 5  
Date 06-01-12

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1	26.00	1.049		0.0	10.000	21.556			K Factor = 5.60	
to		120		0.0	0.0	0.0				
2	26.0	0.2114		0.0	10.000	2.114			Vel = 9.65	
2	27.25	1.049		0.0	9.000	23.670			K Factor = 5.60	
to		120		0.0	0.0	0.0				
3	53.25	0.7964		0.0	9.000	7.168			Vel = 19.77	
3	31.09	1.38		0.0	10.000	30.838			K Factor = 5.60	
to		120		0.0	0.0	0.0				
4	84.34	0.4904		0.0	10.000	4.904			Vel = 18.09	
4	33.48	1.61	1T	8.0	5.500	35.742			K Factor = 5.60	
to		120		0.0	8.000	7.709				
20	117.82	0.4298		0.0	13.500	5.802			Vel = 18.57	
	0.0									
	117.82					49.253			K Factor = 16.79	
5	34.58	1.049	1T	5.0	4.500	38.139			K Factor = 5.60	
to		120		0.0	5.000	7.709				
20	34.58	0.3584		0.0	9.500	3.405			Vel = 12.84	
	0.0									
	34.58					49.253			K Factor = 4.93	
6	26.09	1.049		0.0	10.000	21.713			K Factor = 5.60	
to		120		0.0	0.0	0.0				
7	26.09	0.2128		0.0	10.000	2.128			Vel = 9.69	
7	27.35	1.049		0.0	9.000	23.841			K Factor = 5.60	
to		120		0.0	0.0	0.0				
8	53.44	0.8017		0.0	9.000	7.215			Vel = 19.84	
8	31.21	1.38		0.0	10.000	31.056			K Factor = 5.60	
to		120		0.0	0.0	0.0				
9	84.65	0.4938		0.0	10.000	4.938			Vel = 18.16	
9	33.59	1.61	1T	8.0	5.500	35.994			K Factor = 5.60	
to		120		0.0	8.000	7.709				
21	118.24	0.4325		0.0	13.500	5.839			Vel = 18.63	
	0.0									
	118.24					49.542			K Factor = 16.80	
10	34.70	1.049	1T	5.0	4.500	38.406			K Factor = 5.60	
to		120		0.0	5.000	7.709				
21	34.7	0.3607		0.0	9.500	3.427			Vel = 12.88	
	0.0									
	34.70					49.542			K Factor = 4.93	
11	36.39	1.61	1T	8.0	5.500	42.221			K Factor = 5.60	
to		120		0.0	8.000	7.709				
22	36.39	0.0489		0.0	13.500	0.660			Vel = 5.73	
	0.0									
	36.39					50.590			K Factor = 5.12	
12	35.14	1.049	1T	5.0	4.500	39.374			K Factor = 5.60	
to		120		0.0	5.000	7.709				
22	35.14	0.3692		0.0	9.500	3.507			Vel = 13.04	
	0.0									
	35.14					50.590			K Factor = 4.94	

Final Calculations - Standard

RESIDENTIAL FIRE PROTECTION  
USM Shop AREA

Page 6  
Date 06-01-12

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
20	152.41	3.26		13.000	49.253				
to		120		0.0	0.0				
21	152.41	0.0222		13.000	0.289		Vel = 5.86		
21	152.94	3.26		13.000	49.542				
to		120		0.0	0.0				
22	305.35	0.0806		13.000	1.048		Vel = 11.74		
22	71.53	3.26	1T	20.159	57.000	50.590			
to		120		0.0	20.159	0.0			
23	376.88	0.1189		0.0	77.159	9.176	Vel = 14.49		
23	0.0	3.26	3E	28.223	24.500	59.766			
to		120		0.0	28.223	0.0			
TR	376.88	0.1189		0.0	52.723	6.270	Vel = 14.49		
TR	0.0	3.26	1Zac	0.0	5.000	66.036			
to		120	1Z	9.408	9.408	4.040	* Fixed loss = 4.04		
BR	376.88	0.1189		0.0	14.408	1.713	Vel = 14.49		
BR	0.0	4.1	1G	2.907	25.000	71.789			
to		140	1T	29.067	31.974	0.0			
UG1	376.88	0.0293		0.0	56.974	1.668	Vel = 9.16		
UG1	250.00	8.27	1G	6.326	75.000	73.457	Qa = 250		
to		140	1T	55.354	61.680	0.0			
TEST	626.88	0.0025		0.0	136.680	0.337	Vel = 3.74		
	0.0								
	626.88				73.794		K Factor = 72.97		