

Eastern Fire

WHITE COPY TO OFFICE

Work Order No:

99413

Auburn Ph 207.795.6314 * Fax 207.782.0566
 Bangor Ph 207.942.8014 * Fax 207.942.5202
 170 Kittyhawk Ave; Auburn, ME 04210
 408 Harlow St; Bangor, ME 04401

I N V O I C E		T O		DATE 7.27.2019		TN	
JOB NAME USM		JOB LOCATION Road DIF		CUST. PO#		CN	
JOB ADDRESS 25 Bedford St		CONTACT Jim		Check one		SPRK <input checked="" type="checkbox"/> ALARM <input checked="" type="checkbox"/> GAS <input type="checkbox"/>	
PHONE 207-671-3470		DESCRIPTION OF WORK COMPLETED					
MATERIALS USED		Flushed drain for					
Y		CVs open					
N/A		Comp on					
N/A		QOD on					
Y		Alarm line on					
N/A		Fire pump on					
Y = Yes / N = No		Blank = NA					
Explain All N's		Couldn't hear any sparks					
System owner is responsible for maintaining adequate heat to prevent freezing, draining low point condensation, providing electricity and promptly reporting and responding to any alarm or supervisory conditions. System owner should purchase copies of applicable NFPA Standards (nfpa.org) including, but not limited to, NFPA 25 and 72.		Could not see water come out of drain it is piped into ground.					
		System ok to be left in operation					
		DESCRIPTION OF WORK REMAINING		Complete <input checked="" type="checkbox"/>		Open <input type="checkbox"/>	
		FIELD PURCHASED MATERIALS AND RENTALS		Arrive Time 12:30		AM or PM AM or PM	
1.				Depart Time			
2.				Off hrs call out		Y or N	
3.				Worker Names		Foreman	
4.						Helper	
ACCEPTED BY		DATE 7.27.19				Design	
FOREMAN		DATE 7.27.19				Fab	
		OFFICE USE				Material	
1. Non-quoted job (T&M) start TN for remaining work (check one)		yes <input type="checkbox"/>		no <input checked="" type="checkbox"/>		Rental	
2. Quoted job installation % complete for billing (TN will remain open till 100%):						Other	
3. If RFQ attached please email for follow up to:						TOTAL	