

CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400

NOTICE OF VIOLATION AND ORDER TO CORRECT

December 19, 2016

Responsible Party 1: UNIVERSITY OF MAINE 107 MAINE AVE BANGOR, ME 04401		
Location 43 BEDFORD ST (Masterton)	CBL 114A H005001	Inspection Date 12/16/2016
Inspector Todd Zsiga	Inspection Type FP Routine Inspection	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must complete the proposed date of completion column by proposing a reasonable timeframe to remedy each violation. This form must be received by the Fire Prevention Bureau no later than 1/15/2017. The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

YOUR FAILURE TO SUBMIT A PLAN OF ACTION BY THE DATE PROVIDED, OR TO CORRECT ANY VIOLATION WITHIN THE APPLICABLE TIME FRAME, MAY RESULT IN LEGAL ACTION AGAINST YOU, THE IMPOSITION OF CIVIL PENALTIES, AND THE PURSUIT OF OTHER LEGAL REMEDIES.

Violation	Proposed Date of Completion
NFPA 13- 8.6.6.1, 8.6.6.2 SPRINKLER HEAD BLOCKED; The clearance between the deflector and the top of storage shall be in 18 inch (457 mm) or greater. Where other standards specify greater clearance to storage minimums, they shall be followed. rooms 120,123,128,129,126, Lights installed in numerous offices blocking sprinkler heads. Need to check throughout building.	
N.F.P.A. 101 CHP. 31.3.3.2 HOLE IN CEILING NEEDS REPAIR; InteriorWall and Ceiling Finish Interior walls and ceiling finish materials complying with 10.2 shall be permitted as follows: 1) Exit enclosures -- Class A or class B 2) Lobbies and corridors--Class A or Class B 3) Other spaces Class A, orClass B, or Class C ceiling tiles room 312	

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau’s discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

Date

Responsible Party

Date

Responsible Party

SEEN AND AGREED

Date

Fire Prevention Bureau