

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



This is to certify that  
UNIVERSITY OF MAINE

Located at  
120 BEDFORD ST

PERMIT ID: 2017-01866      ISSUE DATE: 01/08/2018      CBL: 115 B002001

has permission to **Renovate 1470 sf of existing business use occupancy to meet ADA guidelines. Demolish several interior walls, new LVL struture & interior stud walls, electrical & plumbing work.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ Jason Grant*

*/s/ Jeanie Bourke*

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

USM - Sociology Department, Center for Teaching

***Building Inspections***

**Use Group:** B      **Type:** 5B  
Business - University  
Nonsprinkled  
First floor  
MUBEC/IBC 2009

***Fire Department***

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status of Permit or Schedule an Inspection at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

### **REQUIRED INSPECTIONS:**

Close-in Plumbing/Framing

Electrical Close-in

Final - Commercial

Final - Electric

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2017-01866	<b>Date Applied For:</b> 11/28/2017	<b>CBL:</b> 115 B002001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> University - USM		<b>Proposed Project Description:</b> Renovate 1470 sf of existing business use occupancy to meet ADA guidelines. Demolish several interior walls, new LVL struture & interior stud walls, electrical & plumbing work.		
<b>Dept:</b> Zoning	<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Christina Stacey	<b>Approval Date:</b> 12/06/2017	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Note:</b>				
<b>Conditions:</b>				
1) This permit is not approving any lot coverage or setback requirements for the existing structure. It is approving interior work only.				
2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
<b>Dept:</b> Building Inspecti	<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Jeanie Bourke	<b>Approval Date:</b> 12/22/2017	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Note:</b>				
<b>Conditions:</b>				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
<b>Dept:</b> Engineering DPS	<b>Status:</b> Not Applicable	<b>Reviewer:</b> Benjamin Pearson	<b>Approval Date:</b> 11/30/2017	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Note:</b>				
<b>Conditions:</b>				
1) This approval is non-applicable to Engineering DPW as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Works for any other reason than FOG, please contact 874-8801.				
<b>Dept:</b> Fire	<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Jason Grant	<b>Approval Date:</b> 01/08/2018	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Note:</b>				
<b>Conditions:</b>				
1) This project meets the requirements for needing a Maine State Fire Marshal's Office (SFMO) construction and or barrier free permit. The City of Portland must have a copy of this permit on file before a final inspection or certificate of occupancy can be issued. If the SFMO determines that their permit is not needed then correspondence from the SFMO stating that a permit is not required shall be provided.				
2) All construction shall comply with City Code, Chapter 10. All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 43 and other applicable chapters All construction shall comply with 2009 NFPA 1, Fire Code. This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4). All means of egress to remain accessible at all times. If applicable, all outstanding code violations shall be corrected prior to final inspection.				