

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK CITY OF PORTLAND

Please Read
Application And
Notes, If Any,
Attached

BUILDING DEPARTMENT PERMIT

Permit Number: 041549

This is to certify that Losee Rita H/Dead River Company

has permission to install new 240 gallon oil tank single family home

AT 8 Chamberlain Ave City of Portland 115 C009001

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and work on permit on procedure before this building or part thereof is placed or closed-in. FOUR HOUR NOTICE IS REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. _____

Health Dept. _____

Appeal Board _____

Other _____

Department Name

[Handwritten Signature]
10/28/04

Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 04-1549	Date Applied For: 10/13/2004	CBL: 115 C009001
------------------------------	--	----------------------------

Location of Construction: 8 Chamberlain Ave	Owner Name: Losee Rita H	Owner Address: 8 Chamberlain Ave	Phone:
Business Name:	Contractor Name: Dead River Company	Contractor Address: PO Box 467 Scarborough	Phone (207) 883-9515
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	

Proposed Use: single family home w/ new 240 gallon oil tank	Proposed Project Description: install new 240 gallon oil tank in single family home
---	---

Dept: Zoning **Status:** Approved **Reviewer:** Tammy Munson **Approval Date:** 10/28/2004
Note: **Ok to Issue:**

Dept: Building **Status:** Approved with Conditions **Reviewer:** Tammy Munson **Approval Date:** 10/28/2004
Note: **Ok to Issue:**

1) Installation shall comply with 1993 BOCA Mechanical Code and State of Maine Oil and Solid Fuel Board Laws and Rules



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 8 CHAMBERLAIN ST. Use of Building _____ Date 10/14
 Name and address of owner of appliance RITA LOSEE
115C9 21 WINTER PT RD - WEST BATH, ME.
 Installer's name and address DEAD RIVER CO. 73 PLEASANT HILL RD - SCARBOROUGH, ME
 Telephone 883-9515

Location of appliance:

- Basement
- Attic
- Floor
- Roof

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name:

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # MS 3000 8710
- Gas # _____
- Other _____

Type of Chimney:

- Masonry Lined
Factory built _____
- Metal
Factory Built U.L. Listing # _____
- Direct Vent
Type _____ UL# _____

Type of Fuel Tank

- Oil
- Gas

OCT 12 2004

Size of Tank 240 GALLON

Number of Tanks 1

Distance from Tank to Center of Flame 36 feet.

Cost of Work: \$ 1385.00

Permit Fee: \$ 39.00

Approved

Approved with Conditions

Fire: _____

Ele.: _____

Bldg.: _____

See attached letter or requirement

Inspector's Signature

Date Approved

Signature of Installer

[Signature] DEAD RIVER CO.

Tanks shall be installed on the lowest floor of the building. An exception is allowed if the tank is installed in an attached garage that is not the lowest floor.

5.1.1 Foundations

A poured concrete basement floor provides the best option for a strong, stable and solid base for the tank. If a solid, non-combustible floor is not present the recommendations for outdoor installations (Section 5.2) should be followed.

5.1.2 Tanks legs

Our domestic tanks are provided with four threaded leg supports. Tanks legs shall be 1¼" black iron pipes threaded on one end. Leg sizes shall be 11" at the outlet end and 12" at the opposite end. This gives a slope of ¼" per foot of tank length and provides enough room for the shutoff valve and filter installation.

Threaded legs can allow for some height adjustment (useful in models under 240 gals) but tank base or floor must essentially be leveled. Tank legs shall be vertically straightened to level to support evenly the weight of the tank filled with fuel (2200 lb. ±).

The installer must verify that a minimum slope of ¼" by foot toward the fuel outlet is respected. This is a critical point of the installation and failure to comply with it will render the tank warranty NULL and VOID.

5.1.3 Distance from appliances

- Inside tanks shall be located not less than 5 feet from any direct heat source. Refer to NFPA 31 clauses 7.5.13 and 7.5.14 when it is impractical to respect that clearance.
- Keep in mind that the tank must have all necessary satisfying clearances for maintenance and operation.

CAUTION: DO NOT STORE ANY GOODS ABOVE, UNDER OR IN THE PROXIMITY OF THE TANK.

5.2 Outdoor Installation

Where indoor installation is not possible, aboveground outside tanks shall be located in conformance with the following sections.

5.2.1 General Location

- Tanks must not block building entrances or windows including basement windows.