Inspection Division
Date: 09/10/15

MECHANICAL NOTES
1. DUCTWORK SHALL BE CONSTRUCTED AND SEALED IN ACCORDANCE WITH SMACNA STANDARDS.
2. BRANCH DUCTS SHALL INCLUDE BALANCING DAMPERS.
3. SUPPLY DUCTWORK SHALL BE INSULATED PER ASHRAE 90.1 AND IECC 2012

SECOND FLOOR MECHANICAL PLAN
SCALE - 1/8" = 1'-0"

ROOF MECHANICAL PLAN
SCALE - 1/8" = 1'-0"

UNITED INSURANCE AGENCY

470 FOREST AVE.
PORTLAND, MAINE

CONSULTANTS:

BENNETT ENGINEERING
MECHANICAL • ELECTRICAL
(207) 865-9475

REVISIONS:
ISSUED FOR PERMIT

DATE:	AUGUST 26, 2015
PROJECT No.	xxxxx
DRAWN BY:	JMV
CHECKED BY:	SPDoel
SCALE:	AS NOTED

SHEET TITLE:
MECHANICAL PLANS

M1-1