



**Portland Fire Department**

2/25/2019

RICHARD EDMONDSON  
41 PITT ST  
PORTLAND, ME 04103  
edmo13@gmail.com

CERTIFIED MAIL

RE: 41 PITT ST  
PORTLAND, ME

116 B017001

Page 1 of 2

**NOTICE OF VIOLATION  
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 3/20/2017 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

**A reinspection of your property will take place on 4/4/2019 11:00:00AM .**

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan  
Fire Prevention Bureau  
City of Portland

### NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 101-4.5.3.2, 7.1.10.1	The means of egress shall remain free and unobstructed.	IMMEDIATELY remove all obstructions to the means of egress. Couch and piano in front staircase 1st and 2nd floor	3/21/2017
NFPA 1-10.11.6	No hibachi, grill, or other similar devices used for cooking, heating, or any other purpose shall be used on any balcony, or under any overhanging portion within 10' of any structure.	IMMEDIATELY remove all grills from balconies.	3/21/2017
PFD Rules, 4.6	Unit or suite numbers must be clearly marked on doors, with the first numeral of each residential unit being the floor designation.	All units not marked front or rear	3/27/2017
NFPA 101-31.3.4.5; City Code 10-3(i)	Photoelectric, hardwired with battery backup smoke alarms must be provided in every sleeping room, outside every sleeping area, and on every level, including the basement.	IMMEDIATELY install temporary alarms where required. Fully compliant, permanent alarms must be installed by the date given. 1st and 2nd floor apartment bed rooms	4/19/2017
NFPA 101-31.3.2	Boiler and fuel-fired heaters serving more than one dwelling unit must have 1-hour separation or sprinkler protection.	2 new fuel fired boilers in basement	4/19/2017
NFPA 101-31.2.2.1	1-hour fire rated doors and assemblies required, including self-closing and self-latching mechanisms.	All apartment doors front and rear and basement	3/20/2018