



STATE OF MAINE - DEPARTMENT OF PUBLIC SAFETY  
OFFICE OF STATE FIRE MARSHAL  
45 COMMERCE DR STE 1  
AUGUSTA, ME 04333-0001

## Construction Permit

No.24376

*In accordance with the provisions of M.R.S.A. Title 25, Chapter 317, Sec.317 and Title 5, Section 4594-F, permission is hereby granted to construct or alter the following referenced building according to the plans hitherto filed with the Commissioner and now approved. No departure from application form/plans shall be made without prior approval in writing. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions.*

**Each permit issued shall be displayed at the site of construction.**

**Building:** ROSE FOODS LLC  
**Location:** 428 FOREST AVE, PORTLAND, ME 04101-2014  
**Owner:** ROSE FOODS LLC  
**Owner Address:** 428 FOREST AVE, PORTLAND, ME 04101-2014

Occupancy Type: Business  
Secondary Use: Apartments  
Use Layout: Separated Use  
Sprinkler System  
Fire Alarm System  
Barrier Free  
Construction Mode: Renovation  
Unprotected Wood Frame: Type V (000)  
Final Number of Stories: 1

**Permit Date:** 02/07/2017

**Expiration Date:** 08/06/2017

**Notes and additional requirements:**

Add Class ABC extinguishers in the mercantile floor area as well as the kitchen storage area in the back. This is in addition to the required class K extinguisher in the kitchen. NFPA 96 hood drawings and permit to be submitted at a later date by building owner or building owners contractor installing the hood system.

COMMISSIONER OF PUBLIC SAFETY



STATE OF MAINE - DEPARTMENT OF PUBLIC SAFETY  
OFFICE OF STATE FIRE MARSHAL  
45 COMMERCE DR STE 1  
AUGUSTA, ME 04333-0001

## Construction Permit

**No.24376**

*In accordance with the provisions of M.R.S.A. Title 25, Chapter 317, Sec.317 and Title 5, Section 4594-F, permission is hereby granted to construct or alter the following referenced building according to the plans hitherto filed with the Commissioner and now approved. No departure from application form/plans shall be made without prior approval in writing. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions.*

**Each permit issued shall be displayed at the site of construction.**

**Building:** ROSE FOODS LLC  
**Location:** 428 FOREST AVE, PORTLAND, ME 04101-2014  
**Owner:** ROSE FOODS LLC  
**Owner Address:** 428 FOREST AVE, PORTLAND, ME 04101-2014

Occupancy Type: Business  
Secondary Use: Apartments  
Use Layout: Separated Use  
Sprinkler System  
Fire Alarm System  
Barrier Free  
Construction Mode: Renovation  
Unprotected Wood Frame: Type V (000)  
Final Number of Stories: 1

**Permit Date:** 02/07/2017

**Expiration Date:** 08/06/2017

**Notes and additional requirements:**

Add Class ABC extinguishers in the mercantile floor area as well as the kitchen storage area in the back. This is in addition to the required class K extinguisher in the kitchen. NFPA 96 hood drawings and permit to be submitted at a later date by building owner or building owners contractor installing the hood system.

COMMISSIONER OF PUBLIC SAFETY



STATE OF MAINE - DEPARTMENT OF PUBLIC SAFETY  
OFFICE OF STATE FIRE MARSHAL  
45 COMMERCE DR STE 1  
AUGUSTA, ME 04333-0001

## Construction Permit

No.24376

*In accordance with the provisions of M.R.S.A. Title 25, Chapter 317, Sec.317 and Title 5, Section 4594-F, permission is hereby granted to construct or alter the following referenced building according to the plans hitherto filed with the Commissioner and now approved. No departure from application form/plans shall be made without prior approval in writing. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions.*

**Each permit issued shall be displayed at the site of construction.**

**Building:** ROSE FOODS LLC  
**Location:** 428 FOREST AVE, PORTLAND, ME 04101-2014  
**Owner:** ROSE FOODS LLC  
**Owner Address:** 428 FOREST AVE, PORTLAND, ME 04101-2014

Occupancy Type: Business  
Secondary Use: Apartments  
Use Layout: Separated Use  
Sprinkler System  
Fire Alarm System  
Barrier Free  
Construction Mode: Renovation  
Unprotected Wood Frame: Type V (000)  
Final Number of Stories: 1

**Permit Date:** 02/07/2017

**Expiration Date:** 08/06/2017

**Notes and additional requirements:**

Add Class ABC extinguishers in the mercantile floor area as well as the kitchen storage area in the back. This is in addition to the required class K extinguisher in the kitchen. NFPA 96 hood drawings and permit to be submitted at a later date by building owner or building owners contractor installing the hood system.

COMMISSIONER OF PUBLIC SAFETY



STATE OF MAINE - DEPARTMENT OF PUBLIC SAFETY  
OFFICE OF STATE FIRE MARSHAL  
45 COMMERCE DR STE 1  
AUGUSTA, ME 04333-0001

## Construction Permit

**No.24376**

*In accordance with the provisions of M.R.S.A. Title 25, Chapter 317, Sec.317 and Title 5, Section 4594-F, permission is hereby granted to construct or alter the following referenced building according to the plans hitherto filed with the Commissioner and now approved. No departure from application form/plans shall be made without prior approval in writing. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions.*

**Each permit issued shall be displayed at the site of construction.**

**Building:** ROSE FOODS LLC  
**Location:** 428 FOREST AVE, PORTLAND, ME 04101-2014  
**Owner:** ROSE FOODS LLC  
**Owner Address:** 428 FOREST AVE, PORTLAND, ME 04101-2014

Occupancy Type: Business  
Secondary Use: Apartments  
Use Layout: Separated Use  
Sprinkler System  
Fire Alarm System  
Barrier Free  
Construction Mode: Renovation  
Unprotected Wood Frame: Type V (000)  
Final Number of Stories: 1

**Permit Date:** 02/07/2017

**Expiration Date:** 08/06/2017

**Notes and additional requirements:**

Add Class ABC extinguishers in the mercantile floor area as well as the kitchen storage area in the back. This is in addition to the required class K extinguisher in the kitchen. NFPA 96 hood drawings and permit to be submitted at a later date by building owner or building owners contractor installing the hood system.

COMMISSIONER OF PUBLIC SAFETY