STATE OF MAINE - DEPARTMENT OF PUBLIC SAFETY
OFFICE OF STATE FIRE MARSHAL
45 COMMERCE DR STE 1
AUGUSTA, ME 04333-0001

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/11/17

Construction Permit

No. 24376

In accordance with the provisions of M.R.S.A. Title 25, Chapter 317, Sec.317 and Title 5, Section 4594-F, permission is hereby granted to construct or alter the following referenced building according to the plans hitherto filed with the Commissioner and now approved. No departure from application form/plans shall be made without prior approval in writing. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions.

Each permit issued shall be displayed at the site of construction.

Building: ROSE FOODS LLC
Location: 428 FOREST AVE, PORTLAND, ME 04101-2014
Owner: ROSE FOODS LLC
Owner Address: 428 FOREST AVE, PORTLAND, ME 04101-2014

Occupancy Type: Business
Secondary Use: Apartments
Use Layout: Separated Use
Sprinkler System
Fire Alarm System
Barrier Free
Construction Mode: Renovation
Unprotected Wood Frame: Type V (000)
Final Number of Stories: 1

Permit Date: 02/07/2017 **Expiration Date:** 08/06/2017

Notes and additional requirements:

Add Class ABC extinguishers in the mercantile floor area as well as the kitchen storage area in the back. This is in addition to the required class K extinguisher in the kitchen. NFPA 96 hood drawings and permit to be submitted at a later date by building owner or building owners contractor installing the hood system.

John E Morris

COMMISSIONER OF PUBLIC SAFETY

Copy 1 - Owner

STATE OF MAINE - DEPARTMENT OF PUBLIC SAFETY
OFFICE OF STATE FIRE MARSHAL
45 COMMERCE DR STE 1
AUGUSTA, ME 04333-0001

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/11/17

Construction Permit

No. 24376

In accordance with the provisions of M.R.S.A. Title 25, Chapter 317, Sec.317 and Title 5, Section 4594-F, permission is hereby granted to construct or alter the following referenced building according to the plans hitherto filed with the Commissioner and now approved. No departure from application form/plans shall be made without prior approval in writing. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions.

Each permit issued shall be displayed at the site of construction.

Building: ROSE FOODS LLC
Location: 428 FOREST AVE, PORTLAND, ME 04101-2014
Owner: ROSE FOODS LLC
Owner Address: 428 FOREST AVE, PORTLAND, ME 04101-2014

Occupancy Type: Business
Secondary Use: Apartments
Use Layout: Separated Use
Sprinkler System
Fire Alarm System
Barrier Free
Construction Mode: Renovation
Unprotected Wood Frame: Type V (000)
Final Number of Stories: 1

Permit Date: 02/07/2017 **Expiration Date:** 08/06/2017

Notes and additional requirements:

Add Class ABC extinguishers in the mercantile floor area as well as the kitchen storage area in the back. This is in addition to the required class K extinguisher in the kitchen. NFPA 96 hood drawings and permit to be submitted at a later date by building owner or building owners contractor installing the hood system.

John E Morris

COMMISSIONER OF PUBLIC SAFETY

Copy 2 - Architect

STATE OF MAINE - DEPARTMENT OF PUBLIC SAFETY
OFFICE OF STATE FIRE MARSHAL
45 COMMERCE DR STE 1
AUGUSTA, ME 04333-0001

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/11/17

Construction Permit

No. 24376

In accordance with the provisions of M.R.S.A. Title 25, Chapter 317, Sec.317 and Title 5, Section 4594-F, permission is hereby granted to construct or alter the following referenced building according to the plans hitherto filed with the Commissioner and now approved. No departure from application form/plans shall be made without prior approval in writing. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions.

Each permit issued shall be displayed at the site of construction.

Building: ROSE FOODS LLC
Location: 428 FOREST AVE, PORTLAND, ME 04101-2014
Owner: ROSE FOODS LLC
Owner Address: 428 FOREST AVE, PORTLAND, ME 04101-2014

Occupancy Type: Business
Secondary Use: Apartments
Use Layout: Separated Use
Sprinkler System
Fire Alarm System
Barrier Free
Construction Mode: Renovation
Unprotected Wood Frame: Type V (000)
Final Number of Stories: 1

Permit Date: 02/07/2017 **Expiration Date:** 08/06/2017

Notes and additional requirements:

Add Class ABC extinguishers in the mercantile floor area as well as the kitchen storage area in the back. This is in addition to the required class K extinguisher in the kitchen. NFPA 96 hood drawings and permit to be submitted at a later date by building owner or building owners contractor installing the hood system.

John E Morris

COMMISSIONER OF PUBLIC SAFETY

Copy 1 - Owner

STATE OF MAINE - DEPARTMENT OF PUBLIC SAFETY
OFFICE OF STATE FIRE MARSHAL
45 COMMERCE DR STE 1
AUGUSTA, ME 04333-0001

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/11/17

Construction Permit

No. 24376

In accordance with the provisions of M.R.S.A. Title 25, Chapter 317, Sec.317 and Title 5, Section 4594-F, permission is hereby granted to construct or alter the following referenced building according to the plans hitherto filed with the Commissioner and now approved. No departure from application form/plans shall be made without prior approval in writing. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions.

Each permit issued shall be displayed at the site of construction.

Building: ROSE FOODS LLC
Location: 428 FOREST AVE, PORTLAND, ME 04101-2014
Owner: ROSE FOODS LLC
Owner Address: 428 FOREST AVE, PORTLAND, ME 04101-2014

Occupancy Type: Business
Secondary Use: Apartments
Use Layout: Separated Use
Sprinkler System
Fire Alarm System
Barrier Free
Construction Mode: Renovation
Unprotected Wood Frame: Type V (000)
Final Number of Stories: 1

Permit Date: 02/07/2017 **Expiration Date:** 08/06/2017

Notes and additional requirements:

Add Class ABC extinguishers in the mercantile floor area as well as the kitchen storage area in the back. This is in addition to the required class K extinguisher in the kitchen. NFPA 96 hood drawings and permit to be submitted at a later date by building owner or building owners contractor installing the hood system.

John E Morris

COMMISSIONER OF PUBLIC SAFETY

Copy 2 - Architect