

EXHAUST FAN INFORMATION - Job#3039226

FAN UNIT NO.	TAG	FAN UNIT MODEL #	CFM	ESP.	RPM	HP.	SHR.	#	VOLT	FLA	WEIGHT (LBS.)	SONES
1		3880FA	1900	2.000	1297	2.003	0.9973	3	208	6.1	201	17.1

MUA FAN INFORMATION - Job#3039226

FAN UNIT NO.	TAG	FAN UNIT MODEL #	BLOWER	HOUSING	DESIGN CFM	ESP.	RPM	HP.	SHR.	#	VOLT	FLA	WEIGHT (LBS.)	SONES
2		AI-025	Q100	AI	1440	0.330	739	1.000	0.3400	1	115	10.2	260	14.3

FAN OPTIONS

FAN UNIT NO.	TAG	OPTION (Qty. - Desc.)
1		1 - Grease Box
		1 - Full Grating For Exhaust Fans
		1 - 3 Year Extended Motor Warranty
		1 - Fan Base Ceramic Seal - Shim Loose - For Grease Ducts
2		1 - Hinge Kit - Shim Loose For Curb Supplied by Others
		1 - Full Grating For Untempered Fans
		1 - 3 Year Extended Motor Warranty
		1 - Gravity Backdraft Damper for Size 1 Housing
		1 - Wall Mount Option for Size 1 Untempered Fan
		1 - ECR Wiring Package-Supply - PWM Signal from ECPMS Pressure ORSEC Motor

FAN ACCESSORIES

FAN UNIT NO.	TAG	EXHAUST				SUPPLY			
		GREASE CUP	GRAVITY DAMPLER	WALL NEBENT	SIDE ROSECHANGE	GRAVITY DAMPLER	RETORFIZED DAMPLER	WALL NEBENT	
1		YES							
2					YES	YES			YES

FAN SOUND INFORMATION

FAN UNIT NO.	MOTOR	RPM	LVA	SONES	SBA	RESISTANCE 1T	OCTAVE 1	OCTAVE 2	OCTAVE 3	OCTAVE 4	OCTAVE 5	OCTAVE 6	OCTAVE 7	OCTAVE 8
1	Exhaust	1297	81.1	12.1	65.6	5	75.3	78.3	87.1	77	69.9	67.6	62.2	57
2	Supply	739	77.2	14.3	63.7	5	79.1	77.3	75.6	72.6	72.4	70	65.3	62.3

CUSTOMER APPROVAL TO MANUFACTURE

Approved as listed

Approved with NO Exception Taken

Revised and Resubmit

SIGNATURE _____

Your Title _____ Date _____



CAPTIVEAIRE

JOB# Rose Foods RI	
LOCATION SCARBOROUGH, ME.	
DATE 6/2/2017	JOB # 3039226
DWG # 5	DRAWN BY BFC-21
REV.	SCALE 3/8" = 1'-0"