Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 08/01/17

61 FALMOUTH ST.
PORTLAND ME 04103

G3 DECK & STAIRS
@ DRIVE WAY

FRAMING - 2x6 JOIST
4x4 POSTS
5/4x6 PT DECKING

FASTENINGS - SCREWED TO HOUSE 3/8 STRUCTURAL SCREW
16D GALVANIZED NAILS
2 1/2" DECK SCREWS

GUARDS - 4x4 POSTS WITH 2x4 RAILS
1" PIPE GRAB RAIL

STAIRS - 3' WIDE
~~8"~~ RISE w/ 11" RUN
7" max

HEAD RM - open