Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 08/01/17

61 FALMOUTH ST.
PORTLAND ME 04103

G2 STAIR DETAILS
@ OAKDALE ST.

RISE - ~~7 3/4"~~ 7" if possible per IBC for 3 dweilling units

RUN - 11"

HEAD RM - OPEN

GUARDS RAILS - 4x4 POSTS w/ 2x4 PT RAIL
1 1/2" GRAB RAIL

BALISTER - 2x2 PT 4" OC

ADJUSMENT TO ABOVE:

REMOVE EXISTING DECK TO DOOR THEN BRING STAIRS BACK INTO DRIVEWAY.