Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 12/29/17

Legalization Inspection Form

Date: 7/12/2017

Address: 61 Falmouth St

Legal Use: 2 unit

Proposed Use: 3 unit

Common Areas

Basement

- ✓ Fire Door: Needed
- ✓ Detection: A Smoke CO Plus an extra smoke in Basement Because of Separation.
- ✓ Sprinkler Head: Needed
- ○ Electrical/panel: OK

Notes: 2 1Fire doors Needed Oakdale Side of Building
1 if Not 2 Needed Falmouth St Side

Unit 3

- ✓ Fire Door: Needed
- ✓ Detection: Update
- ✓ Egress: Needed

Notes: Stairs going up OakDale Side don't meet head Rm Requirements
Kitchen outlets Need to Be GFCI with in 6' of Sink

Unit 2

- ✓ Fire Door: Needed on Falmouth St side.
- ○ Detection:
- ○ Egress:

Notes:

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 12/29/17

Unit 1

- Fire Door: OK
- Detection: OK
- Egress: OK

Notes:

Unit ___

- Fire Door:
- Detection:
- Egress:

Notes:

Unit ___

- Fire Door:
- Detection:
- Egress:

Notes:

Unit ___

- Fire Door:
- Detection:
- Egress:

Notes:

Overall Pass ✓ Fail ___ Follow up Required ✓

Inspector: Duane Hay

Fire Prevention: