



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 39 Falmouth St Use of Building 3 Unit Apts. Date 4/9/13
 Name and address of owner of appliance Sue Kuntz YEAN
39 Falmouth St. Portland
 Installer's name and address Enclinas HVAC Services Inc. 2 Washington Ave.
Scarborough Me 04074 Telephone 835-0771

Location of appliance:

- Basement
- Floor 1st
- Attic
- Roof
- 2nd
- 3rd

Type of Fuel:

- Gas
- Oil

Appliance Name: Rinnai
 U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # _____
- Other _____

Type of Chimney:

- Masonry Lined
- Factory built _____

- Metal
- Factory Built U.L. Listing # _____

Direct Vent
 Type Rinnai UL# _____

Type of Fuel Tank

- Oil 3x
- Gas

Size of Tank _____

Number of Tanks _____

Distance from Tank to Center of Flame _____ feet.

Cost of Work: ~~\$ 7,842.~~ 8000

Permit Fee: \$ 100

Approved

Fire: _____
 Ele.: _____
 Bldg.: _____

Approved with Conditions

- See attached letter or requirement

Signature of Installer Brian M. Little Inspector's Signature _____ Date Approved _____

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

ARTINYAN ARMAN A & ARTO ARTINYAN/Gelinas
HVAC Services Inc.

Located at

37 FALMOUTH ST

PERMIT ID: 2013-00691 **ISSUE DATE:** 04/29/2013 **CBL:** 116 D029001

has permission to **HVAC; install 3 Rinnai heaters, units/floors 1, 2, & 3.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

Fire Prevention Officer



Code Enforcement Officer / Plan Reviewer

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

REQUIRED INSPECTIONS:

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 2013-00691	Date Applied For: 04/09/2013	CBL: 116 D029001
---------------------------------	--	----------------------------

Location of Construction: 37 FALMOUTH ST	Owner Name: ARTINYAN ARMAN A & ARTO	Owner Address: 150 NOYES ST	Phone:
Business Name:	Contractor Name: Gelinas HVAC Services Inc.	Contractor Address: 2 Washington Ave Scarborough	Phone (207) 885-0771
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	

Proposed Use: Same: Three family dwelling	Proposed Project Description: HVAC; install 3 Rinnai heaters, units/floors 1, 2, & 3.
---	---

Dept: Zoning	Status: Approved	Reviewer: Marge Schmuckal	Approval Date: 04/22/2013
Note:	Ok to Issue: <input checked="" type="checkbox"/>		

Dept: Building	Status: Approved w/Conditions	Reviewer: Tammy Munson	Approval Date: 04/26/2013
Note:	Ok to Issue: <input checked="" type="checkbox"/>		
1) Penetrations through fire resistance rated assemblies shall be protected by an approved penetration firestop system installed as tested in accordance with ASTM E814 or UL 1479 2) The installation must comply with the State of Maine Gas Regulations.			

Dept: Fire	Status: Approved w/Conditions	Reviewer: Chris Pirone	Approval Date: 04/22/2013
Note:	Ok to Issue: <input checked="" type="checkbox"/>		
1) Installation shall comply with NFPA 211, Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances; NFPA 54, National Fuel Gas Code; NFPA 70, National Electrical Code; and the manufacturer's published instructions. 2) Fuel-fired boilers shall be protected in accordance with NFPA 101, Life Safety Code. 3) Installation shall comply with City Code Chapter 10.			