

Paul LePage
Governor



**Maine Department of Public Safety
State Fire Marshal's Office
52 State House Station
Augusta, Maine 04333-0052**



John Morris
Commissioner
Chief Joseph Thomas
State Fire Marshal
Phone: 207-626-3870
Fax: 207-287-6251

Statement of Deficiencies and Plan of Corrections

Facility Name: 500 Forest Avenue Ste.6 – USA Family Well-Being Services	Owner Name: Martin Sungoyo
Location: 500 Forest Ave Ste 6 Portland, ME 04101	Address: SAME
Facility Type: Mental Health Office	Date: January 13, 2017
Telephone : 207- 415 - 5081	
Resource ID : 733154 File : 83260	
During an inspection of your facility a certified State Inspector has found the following violations.	In this right hand column you are required to indicate how and when you will have these violations corrected. Complete this information and return this "Plan of Correction" to the above address within 10 days of receipt of this statement.

- 1) Install exit sign over corridor door.
- 2) Provide the last 4 quarterly sprinkler system inspections including the last 5 year internal inspection.
- 3) Provide the last annual fire alarm report.
- 4) Need fire department connection for building.

Portland Fire Department
Pending P.O.C.

Date of Inspection: 12/22/16
Inspector: Brittany M. Peters
cc:

Owner/Occupant Signature:
Date: