

**City of Portland, Maine - Building or Use Permit Application**

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 07-0286	Issue Date:	CBL: 116 A025001
-----------------------	-------------	---------------------

Location of Construction: 55 WILLIAM ST	Owner Name: WEST COMPANY	Owner Address: 104 GRANT ST	Phone:
Business Name:	Contractor Name: Darling Plumbing & Heating	Contractor Address: 27 Vannah Ave Portland	Phone: 2077739525
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	Zone: RS


Past Use: Residential multi unit	Proposed Use: Residential multi unit Install a Burnham Gas Boiler in basement  <i>legal use - 12 d.v. (per assessor's 1953 card)</i>	Permit Fee: \$170.00	Cost of Work: \$15,000.00	CEO District: 2
		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied <i>Rated Room</i>	INSPECTION: Use Group: <i>R2</i> Type: <i>SB</i>  <i>IBC 2003</i>	

Proposed Project Description: Install a Burnham Gas Boiler in basement	Signature: <i>Greg Cass</i>	Signature: <i>Jm 4/12/07</i>
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied		
Signature: _____ Date: _____		

Permit Taken By: dmartin	Date Applied For: 03/21/2007	<b>Zoning Approval</b>
-----------------------------	---------------------------------	------------------------

- This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.
- Building permits do not include plumbing, septic or electrical work.
- Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

Special Zone or Reviews	Zoning Appeal	Historic Preservation
<input type="checkbox"/> Shoreland	<input type="checkbox"/> Variance	<input checked="" type="checkbox"/> Not in District or Landmark
<input type="checkbox"/> Wetland	<input type="checkbox"/> Miscellaneous	<input type="checkbox"/> Does Not Require Review
<input type="checkbox"/> Flood Zone	<input type="checkbox"/> Conditional Use	<input type="checkbox"/> Requires Review
<input type="checkbox"/> Subdivision	<input type="checkbox"/> Interpretation	<input type="checkbox"/> Approved
<input type="checkbox"/> Site Plan	<input type="checkbox"/> Approved	<input type="checkbox"/> Approved w/Conditions
Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/>	<input type="checkbox"/> Denied	<input type="checkbox"/> Denied <i>ABM</i>
<i>OK</i> Date: <i>3/22/07 ABM</i>	Date: _____	Date: _____



**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE



FILL IN AND SIGN WITH INK

116 19 025

# APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

PERMIT ISSUED  
APR 12  
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 55 William St Use of Building Multi Unit Date 3/20/07

Name and address of owner of appliance West Corp 104 Grant Portland, ME 04102

Installer's name and address Dartm Plumbing & Heating Inc  
27 Hannah Ave Portland, ME 04103 Telephone 773-9925

### Location of appliance:

- Basement
- Attic
- Floor
- Roof

### Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name: Burham V-9

U.L. Approved  Yes  No

Will appliance be installed in accordance with the manufacture's installation instructions?  Yes  No

IF NO Explain: \_\_\_\_\_

### The Type of License of Installer:

- Master Plumber # 07140
- Solid Fuel # \_\_\_\_\_
- Oil # \_\_\_\_\_
- Gas # 473
- Other \_\_\_\_\_

### Type of Chimney:

Masonry Lined  
Factory built Lined chimney

Metal  
Factory Built U.L. Listing # \_\_\_\_\_

Direct Vent  
Type \_\_\_\_\_ UL# \_\_\_\_\_

### Type of Fuel Tank

- Oil
- Gas

Size of Tank \_\_\_\_\_

Number of Tanks \_\_\_\_\_

Distance from Tank to Center of Flame \_\_\_\_\_ feet.

Cost of Work: \$ 15,000

Permit Fee: \$ \_\_\_\_\_

DEPT. OF BUILDING INSPECTION  
CITY OF PORTLAND, ME

Approved

MAR 20 2007

RECEIVED

Approved with Conditions

See attached letter or requirement

Fire: \_\_\_\_\_

Ele.: \_\_\_\_\_

Bldg.: \_\_\_\_\_

Inspector's Signature \_\_\_\_\_

Date Approved \_\_\_\_\_

Signature of Installer \_\_\_\_\_

White - Inspection    Yellow - File    Pink - Applicant's    Gold - Assessor's Copy

#4903

**City of Portland, Maine - Building or Use Permit**

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

<b>Permit No:</b> 07-0286	<b>Date Applied For:</b> 03/21/2007	<b>CBL:</b> 116 A025001
------------------------------	--	----------------------------

<b>Location of Construction:</b> 55 WILLIAM ST	<b>Owner Name:</b> WEST COMPANY	<b>Owner Address:</b> 104 GRANT ST	<b>Phone:</b>
<b>Business Name:</b>	<b>Contractor Name:</b> Darling Plumbing & Heating	<b>Contractor Address:</b> 27 Vannah Ave Portland	<b>Phone</b> (207) 773-9525
<b>Lessee/Buyer's Name</b>	<b>Phone:</b>	<b>Permit Type:</b> HVAC	

<b>Proposed Use:</b> Residential multi unit Install a Burnham Gas Boiler in basement	<b>Proposed Project Description:</b> Install a Burnham Gas Boiler in basement
---	--

**Dept:** Zoning      **Status:** Approved      **Reviewer:** Ann Machado      **Approval Date:** 03/22/2007  
**Note:** Legal use 12 dwelling units per assessor's 1953 record.      **Ok to Issue:**

**Dept:** Building      **Status:** Approved with Conditions      **Reviewer:** Tom Markley      **Approval Date:** 04/12/2007  
**Note:**      **Ok to Issue:**

- 1) The installation must comply with the State of Maine Gas Regulations.
- 2) Application approval based upon information provided by applicant. Any deviation from approved plans requires separate review and approval prior to work.

**Dept:** Fire      **Status:** Approved with Conditions      **Reviewer:** Cptn Greg Cass      **Approval Date:** 03/22/2007  
**Note:**      **Ok to Issue:**

- 1) Room where boiler to be installed requires 1 hr. Fire separation.
- 2) Install shall comply with NFPA 54