

117 Dartmouth Street

Jonathan Lobo <jglobozzo@gmail.com>
To: Glenn Harmon <gharmon@portlandmaine.gov>

Thu, Dec 28, 2017 at 7:51 AM

Glenn,

We will be using the DC 315 thermal paint on the surface of the foam, this is a fire retardant paint. Please let me know if you have any other questions. Thanks, -JL

[Quoted text hidden]