Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/09/18

Note: fasten sheathing to second floor porch framing with 10d ring shank nails @6" o.c.

PORCH SECTION + DETAILS

Proposed Front Porch

scale: 1/4"=1'

STATE OF MAINE
NATHAN R. MERRILL
No. 12279
LICENSED
PROFESSIONAL ENGINEER

117 Dartmouth
Portland, ME

Albert Putnam Associates LLC
02/23/2018