

9/24/02 Inspected additional cross bracing
from ~~at~~ Rafter, collar tie to exterior wall
plate. Four total ~~additional~~ braces installed.
All openings in Roof & wall openings secured
with plywood. Access prohibited
Send letter of Compliance. JB

9/15/02 66 Orland

Jim Moran

the Handyman

no job too small • affordable rates • insured
772-0908

Permit #01-1275
66 Orland
119-D-3