CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 01/05/16

PROJECT LOCATION: 263 BRIGHTON AVE
PORTLAND ME.

HOME OWNER: SANDRA CHAUSSEE

CONTRACTOR: DUBE PLUS CONSTRUCTION

CONTACT PERSON(S) DAVID M ROBERGE
603-923-3308
ELLEN HAYES
603-475-5761

WINDOW SCHEDULE:

(A) 39" x 60"
(B) 32½" x 41"
(C) 27" x 48"
(D) 32" x 62"
(E) 43" x 50"
(F) 70" x 78" - (DOUBLE DOOR EGRESS)
(G) 32" x 37"
(H) 32 x 60"
(I) 30½" x 39"
(J) 32½ x 68"

(S) CURRENT SMOKE DETEC.

(AS) TO BE ADDED SMOKE DETEC.

NOTES:

1. BASEMENT HAS EGRESS OF AN EXTERIOR DOOR 30" x 57"
2. ALL SMOKES TO BE INTER. CONNECTED
3. NEW WALLS TO BE CONSTRUCTED DONE IN 5/8 SHEET ROCK BOTH SIDEDS AND INSULATED
4. BEAM NEEDED TO BE INSTALLED IN KITCHEN SIZE 1¾ x 9½ (4) JOINED TOGETHER W/ 12D NAILS OR SCREWS. FLOOR WEIGHT ABOVE