CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 01/05/16

ATTIC ROOM

* STORAGE ONLY HAS ONLY ONE EGRESS