CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 12/29/14

TO SCALE

- EXISTING ATTIC SPACE TO BE FINISHED - JUST FRAMING TO MEET CODE
- KNEE WALLS + PARTITION WALLS TO BE 2"x4" STUDS @ 60" ON CENTER.
- NO STRUCTURAL CHANGES
- RAILING FOR STAIRS WILL BE UPGRADED TO MEET CODE
- INSULATION WILL BE R-21 5½" D WALL