RESURGAM CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 10/02/14

Provide thickness of wall, floor and roof sheathing.
Walls:7/16" OSB, Floor:3/4" Advantec
Roof: 5/8" CDX

Provide attic access per R807 of the 2009 IRC. Through main house access

Provide R value of insulation in floors, walls and ceilings/roof rafters.
Floors R-30, Walls R-21, Ceiling R-49

Provide separation from the garage to the living space above per R302.5.

Section - Facing North

Scale 1/2" = 1' 0"